

E & A Consulting Group, Inc.  
 10909 Mill Valley Road, Suite 100  
 Omaha, NE 68154  
 tel 402.895.4700  
 fax 402.895.3599  
 www.eacg.com



**E & A CONSULTING GROUP, INC.**

*Engineering Answers*

Zachary A. Jilek, CPESC, CISEC  
 Environmental Services Dept. Manager

**E&A- P2020.056.003**

Inspector: Alex Brown		Stage
Project Name:	<b>5Ds Transportation Trucking Terminal IA - 39263 - 38898</b>	1
For Week Ending:	<b>7/2/2022</b>	<b>51501</b>
Project Location:	Southwest of S 29th Street and 21st Avenue in Council Bluffs, IA (Pottawattamie County)	

Grading:	100%			
Sanitary Sewer:	100%			
Storm Sewer:	100%			
Paving:	100%			
Seeding:	100%			
Utilities:	100%			
Overall Development:	100%			

RAIN FALL AMOUNTS	Amount in tenths	Date inspected	Weather Conditions	Time	
					<b>Week 1</b>
Sunday	0.00"				
Monday	0.00"				
Tuesday	0.00"	6/28/2022	Sunny 88/61	1:20 PM	
Wednesday	0.00"				
Thursday	0.00"				
Friday	0.29"				
Saturday	0.00"				

Complaints:	None
-------------	------

**Construction Sequencing:**

**Which portion(s) (i.e. drainage basins) of the site have had a temporary or permanent cessation of grading, earthwork, or ground disturbance in the last 14 days?**  
 Rough grading began on site (6/29/21). Began shaping PCSMP basin (7/20/21). Sanitary installation began on site (8/24/21). Paving on southern part of the site (9/21/21). Storm sewer installation began on site (9/28/21). Grading and sidewalk installation (12/14/21). Grading along the northern perimeter ROW (3/1/22). Grading ceased (3/8/22). Minor excavation for sprinkler system (4/12/22). Fine grading (4/26/22).

**Which portion(s) (i.e. drainage basins) of the site do not have grading, earthwork, or ground disturbance scheduled in the next 14 days?**  
 Rough grading began on site (6/29/21). Began shaping PCSMP basin (7/20/21). Sanitary installation began on site (8/24/21). Paving on southern part of the site (9/21/21). Storm sewer installation began on site (9/28/21). Grading and sidewalk installation (12/14/21). Grading along the northern perimeter ROW (3/1/22). Grading ceased (3/8/22). Minor excavation for sprinkler system (4/12/22). Fine grading (4/26/22).

**What temporary or permanent stabilization measures listed in this section are being implemented?**  
 Existing vegetation (6/29/21). Seeding / matting PCSMP basin (5/10/22). Sodding throughout the site (5/17/22).

**Checklist Questions:**

**Are receiving waters adjacent to the project free of any significant signs of erosion or sediment that would be associated with the construction activity?**

Yes  
**Create Corrective Action?**  
 N/A

**Have disturbed areas been seeded or otherwise stabilized as required? List inactive portions of the project and if stabilization measure are adequate or needed to prevent erosion.**

Yes  
**Create Corrective Action?**  
 N/A

**Are waste materials (concrete, construction material, hazardous, etc.) being managed properly?**

Yes  
**Create Corrective Action?**  
 N/A


**Are construction entrances and adjacent streets being maintained adequately?**

Yes  
**Create Corrective Action?**  
 N/A

**Is dust associated with the construction activity adequately controlled on the site?**

Yes
<b>Create Corrective Action?</b>
N/A
<b>Comments:</b>
<b>Comments:</b> 1.) Site is in use as a trucking terminal. 2.) Rich Engdahl began shaping the PCSMP basin on the western portion of the site during the inspection on 7/20/21. Rich Engdahl seeded / matted the basin prior to the 5/10/22 inspection.
<b>Findings / Corrective Actions (Date):</b>
<b>Findings / Corrective Actions (Date):</b> 1.) No maintenance is required in the BMP section. 2.) Rich Engdahl seeded / matted the basin prior to the 5/10/22 inspection. Rich Engdahl sodded the remainder of the site prior to the 5/17/22 inspection. E&A inspector will continue to monitor for vegetative growth in the PCSMP basin.

Unique Name	Type	Location	Projected Install Date	Status	Maintenance
CE 01	Construction Entrance	J3		Removed	
<b>Current Condition:</b>	Removed - Rich Engdahl paved the entrance prior to the inspection on 12/21/21.				
CE 02	Construction Entrance	Z7		Removed	
<b>Current Condition:</b>	Removed - Rich Engdahl paved the construction entrance prior to the inspection on 12/14/21.				
CW 01	Concrete Washout	On Site		Removed	
<b>Current Condition:</b>	Removed - Rich Engdahl removed the concrete washout prior to the inspection on 3/1/22.				
D 01	Diversion Check	Z6 to Z8		Removed	
<b>Current Condition:</b>	Removed - The diversion check was regraded prior to the inspection on 8/10/21.				
IP 01	Inlet Protection	F13	8/29/2021	Active	No
<b>Current Condition:</b>	Active - Rich Engdahl installed the inlet prior to the inspection on 12/21/21. Due to the area being paved, inlet protection is not recommended at this time. E&A inspector will continue to monitor.				
IP 02	Inlet Protection	F3	6/29/2021	Active	No
<b>Current Condition:</b>	Active - This is an existing inlet located off of 21st Avenue. Rich Engdahl installed inlet protection prior to the 3/22/22 inspection. Rich Engdahl removed the inlet protection prior to the 6/7/22 inspection. Construction is complete and the area is sodded, so reinstallation will not be recommended.				
IP 03	Inlet Protection	F2	6/29/2021	Active	No
<b>Current Condition:</b>	Active - This is an existing inlet located off of 21st Avenue. Due to the location of the inlet no BMP recommendation is needed at this time. E&A inspector will continue to monitor.				
IP 04	Inlet Protection	M4	8/29/2021	Active	No
<b>Current Condition:</b>	Active - Rich Engdahl installed the inlet prior to the inspection on 10/26/21. Due to the area being paved, inlet protection is not recommended at this time. E&A inspector will continue to monitor.				
IP 05	Inlet Protection	P3	6/29/2021	Active	No
<b>Current Condition:</b>	Active - This is an existing inlet located off of 21st Avenue. Rich Engdahl installed inlet protection prior to the 3/22/22 inspection. Rich Engdahl removed the inlet protection prior to the 6/7/22 inspection. Construction is complete and the area is sodded, so reinstallation will not be recommended.				
IP 06	Inlet Protection	P2	6/29/2021	Active	No
<b>Current Condition:</b>	Active - This is an existing inlet located off of 21st Avenue. Due to the location of the inlet no BMP recommendation is needed at this time. E&A inspector will continue to monitor.				
IP 07	Inlet Protection	Q4	10/5/2021	Active	No
<b>Current Condition:</b>	Active - Rich Engdahl installed the inlet prior to the inspection on 10/05/21. Due to the area being paved, inlet protection is not recommended at this time. E&A inspector will continue to monitor.				
IP 08	Inlet Protection	U4	10/5/2021	Active	No
<b>Current Condition:</b>	Active - Rich Engdahl installed the inlet and inlet protection prior to the inspection on 10/05/21. Rich Engdahl removed the inlet protection prior to the 6/7/22 inspection. Construction is complete and the area is sodded, so reinstallation will not be recommended.				
IP 09	Inlet Protection	X3	6/29/2021	Active	No
<b>Current Condition:</b>	Active - This is an existing inlet located off of 21st Avenue. Rich Engdahl installed inlet protection prior to the 3/22/22 inspection. Rich Engdahl removed the inlet protection prior to the 6/7/22 inspection. Construction is complete and the area is sodded, so reinstallation will not be recommended.				
IP 10	Inlet Protection	X2	6/29/2021	Active	No
<b>Current Condition:</b>	Active - This is an existing inlet located off of 21st Avenue. Due to the location of the inlet no BMP recommendation is needed at this time. E&A inspector will continue to monitor.				
IP 11	Inlet Protection	Y6	10/5/2021	Active	No
<b>Current Condition:</b>	Active - Rich Engdahl installed the inlet and inlet protection prior to the inspection on 10/05/21. Rich Engdahl removed the inlet protection prior to the 6/7/22 inspection. Construction is complete and the area is sodded, so reinstallation will not be recommended.				
IP 12	Inlet Protection	Y7	10/5/2021	Active	No
<b>Current Condition:</b>	Active - Rich Engdahl installed the inlet and inlet protection prior to the inspection on 10/05/21. Rich Engdahl removed the inlet protection prior to the inspection on 11/23/21. Due to the area being paved, reinstallation is not recommended at this time. E&A inspector will continue to monitor.				
IP 13	Inlet Protection	Y8	10/5/2021	Active	No
<b>Current Condition:</b>	Active - Rich Engdahl installed the inlet and inlet protection prior to the inspection on 10/05/21. Rich Engdahl removed the inlet protection prior to the inspection on 11/23/21. Due to the area being paved, reinstallation is not recommended at this time. E&A inspector will continue to monitor.				
IP 14	Inlet Protection	Y11	10/5/2021	Active	No
<b>Current Condition:</b>	Active - Rich Engdahl installed the inlet and inlet protection prior to the inspection on 10/05/21. Rich Engdahl removed the inlet protection prior to the 6/7/22 inspection. Construction is complete and the area is sodded, so reinstallation will not be recommended.				
PB 01	Portable toilet	On Site		Removed	

<b>Current Condition:</b>	Removed - Rich Engdahl removed the portable toilet prior to the 5/17/22 inspection.				
SF 01 - SF 06	Silt Fence	G3 to B15		Removed	
<b>Current Condition:</b>	Removed - The city inspector pre-approved removal of SF 3-6 on 9/23/21. SF 3 and 4 were removed prior to the inspection on 10/05/21. Rich Engdahl removed the remaining section of SF 6 prior to the inspection on 11/30/21. As of 11/30/21, the City has approved silt fence removal in this area for sprinkler installation. Rich Engdahl removed all silt fence prior to the inspection on 12/14/21.				
SF 07 - SF 12	Silt Fence	B16 to P12		Removed	
<b>Current Condition:</b>	Removed - As of 11/30/21, the City has approved silt fence removal in this area. Rich Engdahl removed a majority of SF 7 - 12 prior to the inspection on 12/7/21. Rich Engdahl removed the remainder of SF 7 - 12 prior to the inspection on 3/8/22.				
SF 13 - SF 17	Silt Fence	S12 to Z5		Removed	
<b>Current Condition:</b>	Removed - As of 11/30/21, the City has approved silt fence removal in this area. Rich Engdahl removed SF 13 and SF 14 prior to the inspection on 12/7/21. Rich Engdahl removed SF 15 - 17 prior to the inspection on 3/8/22.				
SF 18 - SF 22	Silt Fence	Z3 to K3		Removed	
<b>Current Condition:</b>	Removed - Rich Engdahl removed the silt fence posts from SF 18 - 22 prior to the inspection on 12/14/21. Rich Engdahl removed the trenched silt fence fabric prior to the inspection on 3/1/22.				
STR	Streets	On Site	6/29/2021	Active	No
<b>Current Condition:</b>	Good Condition - Rich Engdahl cleaned up the trackout on 21st Ave. prior to the inspection on 9/7/21. Rich Engdahl cleaned up trackout around CE 1 prior to the inspection on 10/12/21. Rick Engdahl cleaned up trackout around CE 02 prior to the inspection on 11/2/21. Minor sedimentation was observed around CE 1 during the 12/14/21 inspection. Rich Engdahl cleaned up the sediment around CE 1 prior to the 12/28/21 inspection. Rich Engdahl cleaned 21st Avenue prior to the 3/22/22 inspection.				
SWPPP Sign 01	SWPPP Signs	Adjacent to CE 1	8/3/2021	Active	No
<b>Current Condition:</b>	Good Condition - The E&A inspector installed the SWPPP sign adjacent to CE 01 during the inspection on 8/3/21. The E&A inspector reinstalled the SWPPP sign during the 2/1/22 inspection. Rich Engdahl relocated the SWPPP sign to S 21st Avenue in anticipation of fine grading / sodding prior to the 4/26/22 inspection.				
<b>Certification Statement</b>	"I certify, under penalty of law, that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gathered and evaluated the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information including the possibility of fines and imprisonment for knowing violations."				
<b>Inspector Signature:</b>				<b>Reviewed By:</b> 