

E & A Consulting Group, Inc.
 10909 Mill Valley Road, Suite 100
 Omaha, NE 68154
 tel 402.895.4700
 fax 402.895.3599
 www.eacg.com



Zachary A. Jilek, CPESC, CISEC
 Environmental Services Dept. Manager

E&A- P2008.207.000

Inspector: Patrick Sechser		Stage 3
Project Name:	Bell Brook NER111506	
For Week Ending:	5/14/2016	
Project Location:	Southwest corner of 192nd and Harrison Street- Omaha, NE (Sarpy County)	68028

Grading:	100%			
Sanitary Sewer:	100%			
Storm Sewer:	100%			
Paving:	100%			
Seeding:	100%			
Utilities:	100%			
Overall Development:	82%			


RAIN FALL AMOUNTS	Amount in tenths	Date inspected	Weather Conditions	
				Week 1
Sunday:	0.00"			
Monday	0.00"			
Tuesday	0.00"			
Wednesday	0.00"			
Thursday	0.00"			
Friday	0.00"			
Saturday	0.00"			
				Week 2
Sunday:	0.07"			
Monday	0.33"			
Tuesday	0.00"			
Wednesday	2.24"			
Thursday	0.07"	4/21/2016	Cloudy 67/52	
Friday	0.00"			
Saturday	0.00"			
				Week 3
Sunday:	0.14"			
Monday	0.01"			
Tuesday	0.13"			
Wednesday	1.73"			
Thursday	0.02"			
Friday	0.00"	4/29/2016	Cloudy 49/45	
Saturday	1.18"			
				Week 4
Sunday:	0.17"			
Monday	0.00"			
Tuesday	0.00"	5/3/2016	70/40 Sunny	
Wednesday	0.03"			
Thursday	0.00"			
Friday	0.00"			
Saturday	0.00"			
				Week 5
Sunday:	0.00"			
Monday	1.18"			
Tuesday	0.00"	5/10/2016	Sunny 77/50	
Wednesday	1.02"			
Thursday	0.00"	5/12/2016	Sunny 69/47	
Friday	0.00"			
Saturday	0.00"			

Complaints:	None
-------------	------

Construction Sequencing:
 Which portion(s) (i.e. drainage basins) of the site have had a temporary or permanent cessation of grading, earthwork, or ground disturbance in the last 14 days?
 Entire Site; grading completed and site seeded prior to 4/2008.
 Which portion(s) (i.e. drainage basins) of the site do not have grading, earthwork, or ground disturbance scheduled in the next 14 days? :

Entire Site; grading completed and site seeded prior to 4/2008.					
What temporary or permanent stabilization measures listed in this section are being implemented?					
Existing Vegetation (4/2008), Harrison St. ROW between 201st and 197th St seed and matting by Sarpy County (8/19/08) Seeding and Matting on the hill south of the ROW between 197th and 199th St. (9/08), seeding and matting on outlot 'O' (3/09), removed basin 8 seeded (05/09), Silt Basin 3 seeded and matted (4/2011); Disturbed area behind sediment basin #7 was re-seeded/matted(10/2011); lots 331-335;340-345 were re-seeded(6/5/12); Basin #7 area was seeded and the area where the outfall was removed was matted (4/29/2014).					
SUMMARY QUESTIONS:					
Are approved entrances and adjacent streets being maintained adequately?					
No					
Are receiving waters adjacent to the project free of any significant signs of erosion or sediment that would be associated with the construction activity?					
Yes					
CHECKLIST QUESTIONS:					
Are waste materials (concrete, construction material, hazardous, etc.) being managed properly?					
Yes					
Is dust associated with the construction activity adequately controlled on the site?					
Yes					
Comments:					
Comments: Home construction is active in many areas of the development as of the last inspections.					
Findings / Corrective Actions (Date):					
Findings / Corrective Actions (Date): 1.) Some maintenance is required in the BMP section.					
Unique Name	Type	Location	Projected Install Date	Status	Maintenance
CW 1	Concrete Washout	Lot 393		Removed	
Current Condition:	Removed-Synergy removed the washout pit prior to 11/13/2015.				
Lot 10	Silt Fence	Lot 10		Removed	
Current Condition:	Removed - Oakwood Homes sodded the lot prior to the 6/25/15 inspection.				
Lot 23	Misc/Other	Lot 23		Removed	
Current Condition:	Removed- Bluestone Builders sodded the lot prior to 9/9/2015.				
Lot 30	Misc/Other	Lot 30		Removed	
Current Condition:	Removed- Prairie Homes removed the eels behind the lot prior to the inspection on 3/25/2015.				
Lot 32	Silt Fence	Lot 32		Removed	
Current Condition:	Removed- Ramm Construction sodded the lot prior to 9/25/2015.				
Lot 41	Silt Fence	Lot 41		Removed	
Current Condition:	Removed- Landmark Homes sodded the lot prior to 9/25/2015.				
Lot 46	Silt Fence	Lot 46		Removed	
Current Condition:	Removed- Vogel sodded the lot prior to 6/12/2015.				
Lot 54	Individual Lot	Lot 54		Removed	
Current Condition:	Removed- Proline Homes sodded the lot prior to 4/21/2016.				
Lot 78	Silt Fence	Lot 78		Removed	
Current Condition:	Removed- Outlot C has been come established as of 6/12/2015.				
Lot 88	Individual Lot	Lot 88		Removed	
Current Condition:	Removed-Proline Homes sodded the lot prior to 4/21/2016.				
Lot 135	Silt Fence	Lot 135		Removed	
Current Condition:	Removed- Lot was sodded by Landmark prior to 6/12/2015.				
Lot 138	Silt Fence	Lot 138	12/15/2015	Active	Yes
Current Condition:	Fair Condition- Pinecrest Homes installed silt fence in the rear prior to 12/15/2015. Pinecrest homes removed the silt fence along the rear of the lot prior to 3/17/2016. Silt fence needs to be reinstalled along the rear of the lot Pinecrest Homes was informed to complete by 3/24/2016. Not done as of the last inspection. Pinecrest Homes was reminded on 5/4/2016.				
Lot 149	Individual Lot	Lot 149	3/17/2016	Active	Yes
Current Condition:	Fair Condition- Dirt was removed from the ROW by Marasco Homes prior to 4/21/2016. Silt fence on the side of the lot needs to be repaired in multiple areas. Marasco Homes was informed to complete by 4/28/2016. Not done as of the last inspection.				
Lot 247	Misc/Other	Lot 247		Removed	
Current Condition:	Removed - Nelson Builders sodded the lot prior to the 5/5/15 inspection.				
Lot 269	Silt Fence	Lot 269		Removed	
Current Condition:	Removed- Landmark Homes sodded the lot prior to 9/25/2015.				
Lot 301	Silt Fence	Lot 301		Removed	
Current Condition:	Removed- Lot was sodded and the silted in area was sodded prior to the inspection on 4/3/2015.				
Lot 306	Silt Fence	Lot 306	5/3/2016	Active	No
Current Condition:	Good Condition-Silt fence was installed on the side and in the rear prior to 5/3/2016 by Landmark Homes.				
Lot 308	Silt Fence	Lot 308		Removed	

Current Condition:	Removed- Lot was sodded by Woodlands prior to 6/12/2015.				
Lot 314	Silt Fence	Lot 314	5/3/2016	Active	No
Current Condition:	Good Condition-Silt fence was installed on the side and in the rear prior to 5/3/2016 by Landmark Homes.				
Lot 315	Silt fence	Lot 315		Removed	
Current Condition:	Removed - Good Life Homes sodded the lot prior to the 5/5/15 inspection.				
Lot 320	Silt Fence	Lot 320		Removed	
Current Condition:	Removed- Lot was sodded by Landmark prior to 11/2/2015.				
Lot 322	Silt Fence	Lot 322	12/15/2015	Active	No
Current Condition:	Good Condition-Landmark Homes installed silt fence in the rear prior to 12/15/2015.				
Lot 324	Silt fence	Lot 324		Removed	
Current Condition:	Removed-Lot was sodded by Landmark Homes prior to 8/29/2015.				
Lot 333	Silt Fence	Lot 333	11/13/2015	Active	Yes
Current Condition:	Fair Condition- Silt fence on the side of the lot needs to be repaired. Landmark Homes was informed to complete by 4/28/2016. Not done as of the last inspection. Landmark was reminded on 4/29/2016.				
Lot 334	Individual Lot	Lot 334		Removed	
Current Condition:	Removed- Landmark Homes sodded the lot prior to 12/15/2015.				
Lot 335	Silt Fence	Lot 335		Removed	
Current Condition:	Removed- Al Belt Homes removed the silt fence prior to 9/9/2015.				
Lot 340	Silt Fence	Lot 340	6/12/2015	Active	No
Current Condition:	Good Condition- Silt fence was fixed by Landmark Homes prior to inspection on 3/17/2016.				
Lot 347	Silt Fence	Lot 347		Removed	
Current Condition:	Removed-Landmark Homes sodded the lot prior to inspection on 8/11/15.				
Lot 348	Silt fence	Lot 348	8/25/2015	Active	Yes
Current Condition:	Active- Lot needs to be sodded. Landmark Homes was informed to complete by 4/28/2016. Not done as of the last inspection. Landmark was reminded on 4/29/2016.				
Lot 360	Silt Fence	Lot 360	1/20/2016	Active	No
Current Condition:	Active- Due to pending sidewalk as of 5/3/2016, E&A will monitor runoff from lot 360 and Denali Homes. E&A will update the report accordingly.				
Lot 361	Silt Fence	Lot 361		Removed	
Current Condition:	Removed- Vogel Construction sodded the lot prior to 6/12/2015.				
Lot 364	Silt Fence	Lot 364		Removed	
Current Condition:	Removed- Renaissance Builders sodded the lot prior to 2/25/2016.				
Lot 367	Silt Fence	Lot 367	3/3/2016	Active	No
Current Condition:	Good Condition- Silt fence was fixed by Landmark Homes prior to inspection on 3/17/2016.				
Lot 370	Silt fence	Lot 370	8/18/2015	Active	No
Current Condition:	Good Condition- Silt fence was installed in the front of the lot by Landmark Homes prior to 8/18/2015.				
Lot 372	Silt Fence	Lot 372	6/23/2014	Active	No
Current Condition:	Good Condition- Woodland Homes repaired the torn and damaged silt fence prior to 12/15/2015.				
Lot 374	Silt fence	Lot 374		Removed	
Current Condition:	Removed - Bluestone Custom Builders sodded the lot prior to the 5/5/15 inspection.				
Lot 378	Silt Fence	Lot 378		Removed	
Current Condition:	Removed - Landmark Homes sodded the lot prior to the 5/5/15 inspection.				
Lot 384	Silt Fence	Lot 384		Removed	
Current Condition:	Removed- Lot was sodded by Landmark prior to 6/12/2015.				
Lot 391	Silt Fence	Lot 391		Removed	
Current Condition:	Removed- Lot was sodded by Landmark prior to 6/12/2015.				
Lot 392	Silt Fence	Lot 392		Removed	
Current Condition:	Removed- Lot was sodded by Landmark prior to 6/12/2015.				
Lot 393	Silt fence	Lot 393	8/18/2015	Active	Yes
Current Condition:	Fair Condition- Silt fence was repaired in the rear and wattles were installed in the front by Landmark Homes prior to 5/12/2016. Silt fence on the front of the lot needs to be repaired/ and the silt needs to be removed from the adjoining yard. Landmark Homes was informed to complete by 4/28/2016. Not done as of the last inspection. Landmark was reminded on 4/29/2016.				
Lot 398	Silt Fence	Lot 398	6/28/3024	Active	Yes
Current Condition:	Fair Condition- Silt fence was reinstalled in the rear by Landmark Homes prior to 5/3/2016. Silt fence on the side needs to be repaired. Landmark Homes was informed to complete by 5/5/2016. Not done as of the last inspection.				
Lot 399	Silt Fence	Lot 399		Removed	
Current Condition:	Removed-Silverstone Builders sodded the lot prior to the inspection on 7/24/2014. Lot 399 will be removed as of				

Lot 421	Silt Fence	Lot 421		Removed	
Current Condition:	Removed - Woodland Homes sodded the lot prior to the 5/5/15 inspection.				
Lot 431	Individual Lot	Lot 431	7/31/2015	Active	No
Current Condition:	Good Condition-Wattles and filter socks were installed in the NE rear prior to 9/9/2015. Additional wattle was added prior to 12/15/2015.				
Lot 432	Silt Fence	Lot 432		Removed	
Current Condition:	Removed- D&E Custom Homes sodded the lot prior to 4/21/2015.				
Lot 461	Silt Fence	Lot 461	12/17/2014	Active	No
Current Condition:	Good Condition- SF was installed in the rear by Landmark Homes prior to the inspection on 12/17/2014.				
Lot 463	Silt Fence	Lot 463	6/12/2015	Active	No
Current Condition:	Good Condition- Silt fence was fixed by Landmark Homes prior to inspection on 3/17/2016.				
Lot 464	Silt Fence	Lot 464		Removed	
Current Condition:	Removed - Landmark Homes sodded the lot prior to the 7/31/15 inspection.				
Lot 482	Silt Fence	Lot 482		Removed	
Current Condition:	Removed- Lot was sodded by Marasco Homes prior to 6/12/2015.				
STR	Streets	Streets	In Place	Active	Yes
Current Condition:	Fair Condition- Denail Homes street cleaned in front of the lot prior to 4/21/2016. Runoff needs to be cleaned from lot 348. Landmark Homes was informed to complete by 4/30/2016. Not done as of the last inspection.				
SWPPP Sign	SWPPP Signs	6 signs	8/19/2008	Active	No
Current Condition:	Good Condition- E&A inspector reinstalled the SWPPP sign at 197th and Harrison during the inspection on 4/11/2014.				
Inspector's Signature:			Reviewed By: 