E & A Consulting Group, Inc. 10909 Mill Valley Road, Suite 100 Omaha, NE 68154 tel 402.895.4700 fax 402.895.3599 www.eacg.com



Zachary A. Jilek, CPESC, CISEC Environmental Services Dept. Manager

Engineering Answers

Land of the Charles Williams			04.000	Ctoro		
Inspector: Chase Wickard		Stage				
		3				
Project Name:		NER111205				
For Week Ending:						
Project Location:	1	68007				
,			ts- Omaha, NE (Douglas County)			
Grading:	100%					
Sanitary Sewer:	100%					
Storm Sewer:	100%					
Paving: Seeding:	100% 100%					
Utilities:	100%					
Overall Development:	90%					
•						
RAIN FALL AMOUNTS	Amount in inches	Date inspected	Weather Conditions			
Sunday	0.00"			Wee		
Sunday: Monday	0.00" 0.00"		+			
ruesday	0.89"	08/15/18	80/67 Rain			
Wednesday	0.17"	33.10/10				
Thursday	0.01"					
Friday	0.00"					
Saturday	0.00"					
Down dieser	0.40"			Wee		
Sunday: Monday	0.40" 0.10"					
Tuesday	0.04"					
Wednesday	0.01"	08/22/18	75/54 Clear			
Thursday	0.00"					
Friday	0.00"					
Saturday	0.00"					
2	0.000			Wee		
Sunday:	0.03" 0.02"					
Monday Tuesday	0.02					
Wednesday	0.00"					
Thursday	0.02"					
Friday	0.03"					
Saturday	0.03"					
				Wee		
Sunday:	0.06"					
Monday Tuesday	0.12" 1.05"					
Nednesday	0.33"	09/05/18	76/63 Rain			
Thursday	0.00"	00/00/10	70,00 ((a))			
Friday	0.00"					
Saturday	0.00"					
				Wee		
Sunday:	NA					
Monday	NA NA					
Tuesday Wednesday	NA NA		+			
Thursday	NA NA					
Friday	NA NA		+ + + + + + + + + + + + + + + + + + + +			
Saturday	NA NA					
·				<u> </u>		
	None					
Complaints:						

Construction Sequencing:

Which portion(s) (i.e. drainage basins) of the site have had a temporary or permanent cessation of grading, earthwork, or ground disturbance in the last 14 days?

Entire Site, grading was completed prior to taking this project over on 8/28/2008.

Entire Site; McArdle completed regarding of the lots 12-18 along 155th Street as of 6/2011.

Which portion(s) (i.e. drainage basins) of the site do not have grading, earthwork, or ground disturbance scheduled in the next 14 days?:

Entire Site, grading was completed prior to taking this project over on 8/28/2008.

Entire Site; McArdle completed regarding of the lots 12-18 along 155th Street as of 6/2011.

What temporary or permanent stabilization measures listed in this section are being implemented?

Existing vegetation / Sod (8-2008), seed on S.B.'B' (removed basin) (4/09), Lots 11-18 was re-seeded (6/2011) Lots 12, 13, 14 were sodded (10/5/2013).

Summary Questions:

Are approved entrances and adjacent streets being maintained adequately?

Yes

Are receiving waters adjacent to the project free of any significant signs of erosion or sediment that would be associated with the construction activity?

res

Checklist Questions:

Are waste materials (concrete, construction material, hazardous, etc.) being managed properly?

Yes

Is dust associated with the construction activity adequately controlled on the site?

Yes

Comments:

Comments:

One house is under construction at this time.

Findings / Corrective Actions (Date)

Findings / Corrective Actions (Date):

Some maintenance is required in the BMP section.

1. Lot 10 needs to be stabilized due to being disturbed from construction. Landmark Homes was informed to complete by 8/31/18. Not done as of the last inspection.

Unique Name	Type	Location	Projected Install Date	Status	Maintenance		
Lot 1 Replat 1	Silt Fence	Lot 21		Removed			
Current Condition:	Removed - Lai	Removed - Landmark Homes sodded the lot prior to the inspection on 8/15/18.					
Lot 2	Silt Fence	Lot 2		Removed			
Current Condition:			the lot prior to the inspec				
Lot 3	Silt Fence	Lot 3		Removed			
Current Condition:	Removed - Lan	dmark Homes sodded	he lot prior to the inspection	on 4/27/18.			
Lot 4	Silt Fence	Lot 4		Removed			
Current Condition:	Removed - Lan	dmark Homes sodded	he lot prior to the 11/1/16 ins	pection.			
Lot 5	Silt Fence	Lot 5		Removed			
Current Condition:	Removed- Lot	was sodded by Landma	rk Homes prior to 6/30/2016.				
Lot 6	Silt Fence	Lot 6		Removed			
Current Condition:		dmark Homes sodded p	rior to 7/16/2015.				
Lot 7	Silt Fence	Lot 7		Removed			
Current Condition:	Removed - Lan	dmark Homes sodded	he lot prior to the 11/1/16 ins	pection.			
Lot 8	Silt Fence	Lot 8	·	Removed			
Current Condition:	Removed - Lan	dmark Homes sodded	he lot prior to the inspection	on 7/27/17.			
Lot 9	Active Lot	Lot 9	·	Removed			
Current Condition:	Removed - Lan	dmark Homes sodded	he lot prior to the inspection	on 7/29/18.			
Lot 12	Silt Fence	Lot 12		Removed			
Current Condition:	Removed-Land	lmark Homes sodded th	e lot prior to inspection on 12	2/15/15.			
Lot 13	Silt Fence	Lot 13		Removed			
Current Condition:	Removed-Land	lmark Homes sodded th	e lot prior to inspection on 12	2/15/15.			
Lot 21	Silt Fence	Lot 21	· ·	Removed			
Current Condition:	Removed - The	lot was mislabeled. Th	e active lot is lot 1 R1.				
Lot 23	Individual Lot	Lot 23	6/20/2018	Active	No		
Current Condition:	on 7/29/18.		talled silt fence on the easter	n side of the lot pri	or to the inspection		
Lot 26	Silt Fence	Lot 26		Removed			
Current Condition:	Removed- See	lot 4 item as of 2/24/20	16.				
Lot 29	Silt Fence	Lot 29		Removed			
Current Condition:	Removed- See	lot 7 item as of 2/24/20	16.				
Lot 33	Individual Lot	Lot 33		Removed			
Current Condition:		to the lot being sodded as of 10/24/2015.	prior by Landmark Homes a	nd vegetation filling	in, silt fence is no		

STR	Streets	N41d11m34s W96d12m23s	8/28/2008	Active	No	
Current Condition:	Good Condition - No track out was observed during the inspection on 7/18/18.					
SWPPP Sign	SWPPP Sign	1 sign	10/27/2008	Active	No	
Current Condition:	Good Condition- Installed on 10-27-08 on 156th and Potter					
Inspector Signature:				Reviewed By:	6.5 S. 1)	