

E&A Consulting Group, Inc.  
 330 North 117th Street  
 Omaha, NE 68154-2509  
 tel 402.895.4700  
 fax 402.895.3599  
 www.eacg.com



E&A CONSULTING GROUP, INC.  
 ENGINEERING • PLANNING • FIELD SERVICES

Zachary A. Jilek, CPESC, CISEC  
 Erosion Control Specialist- Manager

**E&A - P2004.045.000**

Inspector: Mike Jacobson, CISEC		Stage
Project Name:	<b>Meridian Park NER110696</b>	1
For Week Ending:	<b>10/22/2011</b>	
Project Location:	<b>168th &amp; Giles Street- Omaha, NE (Sarpy County)</b>	<b>68136</b>

Grading:	100%			
Sanitary Sewer:	90%			
Storm Sewer:	90%			
Paving:	90%			
Seeding:	100%			
Utilities:	65%			
Overall Development:	20%			

RAIN FALL AMOUNTS	Amount in tenths	Date inspected			
<b>Week 1</b>					
Sunday:	Trace				
Monday	0.17"				
Tuesday	0.00"				
Wednesday	0.00"	10/19/11			
Thursday	0.00"				
Friday	0.00"				
Saturday	0.03"				

Complaints:	None
-------------	------

**Construction Sequencing:**  
 Which portion(s) (i.e. drainage basins) of the site have had a temporary or permanent cessation of grading, earthwork, or ground disturbance in the last 14 days?

Entire Site, grading completed and site seeded Summer/Fall 2005.  
 Entire Site, grading was completed in Replat Three area Lots 1-54 prior to inspection on 10/5/11 by Double D.

Which portion(s) (i.e. drainage basins) of the site do not have grading, earthwork, or ground disturbance scheduled in the next 14 days?

Entire Site, grading completed and site seeded Summer/Fall 2005.  
 Entire Site, grading was completed in Replat Three area Lots 1-54 prior to inspection on 10/5/11 by Double D.


What temporary or permanent stabilization measures listed in this section are being implemented?  
 Site seeded Fall 2005 & 5/2007, stabilized entrances installed Summer 2005, Re-Seed 5/2007 by Geis; Sediment Basin E area seeded (9/2008); Areas around where handicap ramps were installed was re-seeded (4/2009); Sediment basin E area was re-seeded(4/2009)

**Comments:**  
 Home construction remains active on site at this time. Paving was active in Replat three lots 1-54 area by MBC construction.

**Findings / Corrective Actions (Date):**  
**Findings / Corrective Actions (Date):**  
 1) Some maintenance is required in the BMP section.  
 2) There is pile on concrete debris along 165th Street that needs to be cleaned up. S&S trenching was informed to clean up by 10/26/11.

Unique Name	Type	Location	Projected Install Date	Status	Maintenance
CE A	Construction Entrance	N41d00m00s W96d00m00s		Removed	
<b>Current Condition:</b>	Entrance Paved				
CW	Concrete Washout Pit	Along 164th Street		Removed	
<b>Current Condition:</b>	Concrete washout was removed prior to inspection on 7/12/11 by Jeff w/ Hearthstone Production.				

CW 1	Concrete Washout Pit	Along 165th Street	7/12/2011	Active	No
<b>Current Condition:</b>	Good Condition- Washout pit was replaced and the construction debris was cleaned up prior to inspection on 10/19/11 by Jeff w/ Hearthstone Production.				
POD A	Silt Fence	Meridian Park Replat three Lots 1-54	5/4/2010	Active	Yes
<b>Current Condition:</b>	Fair Condition- Silt fence is installed along 164th Street. The damaged section of silt fence was removed due to street construction prior inspection on 10/19/11 by MBC construction.  One area is damaged and full and it needs to be cleaned out and repaired. One area is damaged and it needs to be repaired.  MBC construction was informed to complete maintenance by 10/26/11.				
POD B	Silt Fence	Lots 63-73		Removed	
<b>Current Condition:</b>	Silt fence is no longer needed due to the all lots being sodded in this pod prior to inspection on 6/3/10 by Chris w/ Hearthstone Production.				
POD C	Silt Fence	Lots 97-122		Removed	
<b>Current Condition:</b>	Silt fence is no longer needed due to the all lots being sodded in this pod prior to inspection on 10/5/11 by Jeff w/ Hearthstone Production.				
POD D	Silt Fence	Lots 123-162		Removed	
<b>Current Condition:</b>	Silt fence is no longer needed due to the all lots being sodded in this pod prior to inspection on 10/5/11 by Jeff w/ Hearthstone Production.				
POD E	Silt Fence	Lots 163-199		Removed	
<b>Current Condition:</b>	Silt fence installed on the back of lot 175 was removed prior to inspection on 9/29/10 by Chris w/ Hearthstone Production due to the lot being sodded. All the homes in this pod have been completed.				
POD F	Silt Fence	Lots 209-217	4/16/2011	Active	Yes
<b>Current Condition:</b>	Fair Condition- Silt fence installed on the back lots or the back of the lots 209-212. Dirt piled in the R.O.W. on lots 209 and 210 was removed prior to inspection on Jeff w/ Hearthstone production.  One area on lot 209 has dirt piled on silt fence and it needs to be cleaned out. Silt fence needs to be installed on the back of lot 217.  Jeff w/ Hearthstone production was informed to complete maintenance by 10/26/11.				
SB E	Sediment Basin	N41d00m00s W96d00m00s		Removed	
<b>Current Condition:</b>	Basin was removed due to lot development prior to inspection on 6/12/08 by Double D Excavating.				
SB F	Sediment Basin	N41d00m00s W96d00m00s		Removed	
<b>Current Condition:</b>	As of inspection on 5/12/11 the basin has been filled in by Double D Excavating.				
SB G	Sediment Basin	N41d00m00s W96d00m00s	08/26/05	Active	No
<b>Current Condition:</b>	Good Condition- 15% Filled Partially Cleaned out and baffle repaired prior to inspection on 10/12/10 by Bob Roth.				
SF A	Silt Fence	N41d00m00s W96d00m00s	07/19/05	Removed	
<b>Current Condition:</b>	Removed				
SF B	Silt Fence	N41d00m00s W96d00m00s		Removed	
<b>Current Condition:</b>	Removed - Not needed due to established vegetative cover in area.				
SF C	Silt Fence	N41d00m00s W96d00m00s		Removed	
<b>Current Condition:</b>	Removed - Not needed due to established vegetative cover in area.				
ST A	Silt Trap	N41d00m00s W96d00m00s		Removed	
<b>Current Condition:</b>	Trap Closed June 2006.				
ST B	Sediment Trap	N41d00m00s W96d00m00s		Removed	
<b>Current Condition:</b>	Sediment trap was removed prior to inspection on 10/5/11 due to re-grading of the area by Double D.				

ST C	Sediment Trap	N41d00m00s W96d00m00s		Removed	
<b>Current Condition:</b>	Sediment trap was removed prior to inspection on 10/5/11 due to re-grading of the area by Double D.				
ST D	Sediment Trap	N41d00m00s W96d00m00s		Removed	
<b>Current Condition:</b>	Sediment trap was removed prior to inspection on 10/5/11 due to re-grading of the area by Double D.				
ST 1	Sediment Trap	North of Replat three Lots 1 and 2	10/5/2011	Active	No
<b>Current Condition:</b>	Good Condition- 0% Filled Sediment trap is installed prior to inspection on 10/5/11 by Double D.				
ST 2	Sediment Trap	Southeast corner of Replat three lot 1	10/5/2011	Active	No
<b>Current Condition:</b>	Good Condition- 0% Filled Sediment trap is installed prior to inspection on 10/5/11 by Double D.				
ST 3	Sediment Trap	Northeast corner of Replat three lot 26	10/5/2011	Active	No
<b>Current Condition:</b>	Good Condition- 0% Filled Sediment trap is installed prior to inspection on 10/5/11 by Double D.				
ST 4	Sediment Trap	North of Replat three Lots 27 and 28	10/5/2011	Active	No
<b>Current Condition:</b>	Good Condition- 0% Filled Sediment trap is installed prior to inspection on 10/5/11 by Double D.				
ST 5	Sediment Trap	Southeast corner of Replat three lot 27	10/5/2011	Active	No
<b>Current Condition:</b>	Good Condition- 0% Filled Sediment trap is installed prior to inspection on 10/5/11 by Double D.				
ST 6	Sediment Trap	Northeast corner of Replat three lot 46	10/5/2011	Active	No
<b>Current Condition:</b>	Good Condition- 0% Filled Sediment trap is installed prior to inspection on 10/5/11 by Double D.				
STR	Streets	N41d14m44s W96d12m59s	8/10/2007	Active	Yes
<b>Current Condition:</b>	Fair Condition- Some minor track off along Portal Street and it needs to be cleaned up. Double D excavating was informed to cleaned up by 10/20/11.				
SWPPP Sign	SWPPP Sign	Two signs on site	3/28/2008	Active	No
<b>Current Condition:</b>	Good Condition On 3/28/08 a SWPPP sign was installed at 164th & Giles and 168th & Meridian St. entrance.				
Inspector Signature: 			Reviewed By: 