

E&A Consulting Group, Inc.
 330 North 117th Street
 Omaha, NE 68154-2509
 tel 402.895.4700
 fax 402.895.3599
 www.eacg.com



E&A CONSULTING GROUP, INC.
 ENGINEERING • PLANNING • FIELD SERVICES

Zachary A. Jilek, CPESC, CISEC
 Erosion Control Specialist- Manager

E&A - P2004.045.000

Inspector: Mike Jacobson, CISEC		Stage 3
Project Name:	Meridian Park NER110696	
For Week Ending:	9/8/2012	
Project Location:	168th & Giles Street- Omaha, NE (Sarpy County)	68136

Grading:	100%			
Sanitary Sewer:	90%			
Storm Sewer:	90%			
Paving:	90%			
Seeding:	100%			
Utilities:	65%			
Overall Development:	20%			

RAIN FALL AMOUNTS	Amount in tenths	Date inspected			
Week 1					
Sunday:	0.00"				
Monday	0.00"				
Tuesday	0.00"				
Wednesday	0.01"				
Thursday	0.00"				
Friday	0.00"				
Saturday	0.05"				
Week 2					
Sunday:	0.00"				
Monday	0.00"				
Tuesday	0.00"				
Wednesday	0.00"				
Thursday	0.00"				
Friday	0.11"				
Saturday	0.05"				
Week 3					
Sunday:	0.00"				
Monday	0.00"	08/27/12			
Tuesday	0.00"				
Wednesday	0.00"				
Thursday	0.00"				
Friday	0.00"				
Saturday	0.00"				
Week 4					
Sunday:	0.00"				
Monday	0.01"				
Tuesday	0.00"				
Wednesday	0.00"				
Thursday	0.02"				
Friday	0.00"				
Saturday	0.00"				
Week 5					
Sunday:	N/A	N/A			
Monday	N/A	N/A			
Tuesday	N/A	N/A			
Wednesday	N/A	N/A			
Thursday	N/A	N/A			
Friday	N/A	N/A			
Saturday	N/A	N/A			

Complaints:	None
--------------------	------

Construction Sequencing:
 Which portion(s) (i.e. drainage basins) of the site have had a temporary or permanent cessation of grading, earthwork, or ground disturbance in the last 14 days?


Entire Site, grading completed and site seeded Summer/Fall 2005.

Entire Site, grading was completed in Replat Three area Lots 1-54 prior to inspection on 10/5/11 by Double D.

Which portion(s) (i.e. drainage basins) of the site do not have grading, earthwork, or ground disturbance scheduled in the next 14 days?
Entire Site, grading completed and site seeded Summer/Fall 2005.
Entire Site, grading was completed in Replat Three area Lots 1-54 prior to inspection on 10/5/11 by Double D.
What temporary or permanent stabilization measures listed in this section are being implemented?
Site seeded Fall 2005 & 5/2007, stabilized entrances installed Summer 2005, Re-Seed 5/2007 by Geis; Sediment Basin E area seeded (9/2008); Areas around where handicap ramps were installed was re-seeded (4/2009); Sediment basin E area was re-seeded(4/2009); Replat three lots 1-54 was seeded 10/2011); Replat Three lots 1-54 was re-seeded 4/2012)
Comments:
Comments: A few homes are under construction in the site.
Findings / Corrective Actions (Date):
Findings / Corrective Actions (Date): 1) Some maintenance is required in the BMP section.

Unique Name	Type	Location	Projected Install Date	Status	Maintenance
CE A	Construction Entrance	N41d00m00s W96d00m00s		Removed	
Current Condition:	Entrance Paved				
CW	Concrete Washout Pit	Along 164th Street		Removed	
Current Condition:	Concrete washout was removed prior to inspection on 7/12/11 by Jeff w/ Hearthstone Production.				
CW 1	Concrete Washout Pit	Along 165th Street	7/12/2011	Active	No
Current Condition:	Good Condition- Washout pit was replaced and the construction debris was cleaned up prior to inspection on 10/19/11 by Jeff w/ Hearthstone Production.				
Lot 51	Silt Fence	Lot 51	7/30/2012	Active	Yes
Current Condition:	Fair Condition- One area of silt fence is down/damaged and it needs to be repaired or the silt fence check can be removed. Nic w/ The Home Company was informed to complete maintenance by 8/5/12. On 8/27/12 Nic w/ The home company was reminded that maintenance needs to be completed ASAP.				
Lot 310	Silt Fence	Lot 310		Removed	
Current Condition:	Lot was sodded prior to inspection on 8/27/12 by Nic w/ The Home Company.				
POD B	Silt Fence	Lots 63-73		Removed	
Current Condition:	Silt fence is no longer needed due to the all lots being sodded in this pod prior to inspection on 6/3/10 by Chris w/ Hearthstone Production.				
POD C	Silt Fence	Lots 97-122		Removed	
Current Condition:	Silt fence is no longer needed due to the all lots being sodded in this pod prior to inspection on 10/5/11 by Jeff w/ Hearthstone Production.				
POD D	Silt Fence	Lots 123-162		Removed	
Current Condition:	Silt fence is no longer needed due to the all lots being sodded in this pod prior to inspection on 10/5/11 by Jeff w/ Hearthstone Production.				
POD E	Silt Fence	Lots 163-199		Removed	
Current Condition:	Silt fence installed on the back of lot 175 was removed prior to inspection on 9/29/10 by Chris w/ Hearthstone Production due to the lot being sodded. All the homes in this pod have been completed.				
POD F	Silt Fence	Lots 209-217	4/16/2011	Active	Yes

Current Condition:	<p>Good Condition- Some lot level silt fence needed to be installed on lot 216 not 215 and as of inspection on 8/27/12 lot 216 has been sodded therefore silt fence is no longer needed.</p> <p>Lot 215 and 214 has dirt piled in the R.O.W. and it needs to be removed or add silt fence around it.</p> <p>Nic w/ The Home Company was informed to complete maintenance by 9/5/12. A few extra days was given to complete maintenance due to the long holiday weekend.</p>				
POD E	Silt Fence	Lots 51-56 along Meridian Street	5/2/2012	Active	No
Current Condition:	Good Condition- Maintenance on lot 52 was completed prior to inspection on 6/4/12 by Nic w/ The Home Company.				
SB E	Sediment Basin	N41d00m00s W96d00m00s		Removed	
Current Condition:	Basin was removed due to lot development prior to inspection on 6/12/08 by Double D Excavating.				
SB F	Sediment Basin	N41d00m00s W96d00m00s		Removed	
Current Condition:	As of inspection on 5/12/11 the basin has been filled in by Double D Excavating.				
SB G	Sediment Basin	N41d00m00s W96d00m00s	08/26/05	Active	No
Current Condition:	Good Condition- 15% Filled Partially Cleaned out and baffle repaired prior to inspection on 10/12/10 by Bob Roth.				
SF A	Silt Fence	N41d00m00s W96d00m00s	07/19/05	Removed	
Current Condition:	Removed				
SF B	Silt Fence	N41d00m00s W96d00m00s		Removed	
Current Condition:	Removed - Not needed due to established vegetative cover in area.				
SF C	Silt Fence	N41d00m00s W96d00m00s		Removed	
Current Condition:	Removed - Not needed due to established vegetative cover in area.				
SF 1	Silt Fence	Meridian Park Replat Lot 1	5/4/2010	Active	No
Current Condition:	Good Condition- Silt fence is installed on the Southeast corner of the lot. Maintenance was completed prior to inspection on 5/21/12 by CS for Hearthstone.				
SF 2	Silt Fence	Meridian Park Replat Lots 26, 27	5/4/2010	Active	No
Current Condition:	Good Condition- Silt fence is installed on the Southeast corner of the lot. Maintenance was completed prior to inspection on 8/27/12 by CS for Hearthstone.				
SF 3	Silt Fence	Meridian Park Replat Lots 46, 47	5/4/2010	Active	No
Current Condition:	Good Condition- Silt fence is installed on the Southeast corner of the lot. Maintenance was completed prior to inspection on 5/21/12 by CS for Hearthstone.				
ST A	Silt Trap	N41d00m00s W96d00m00s		Removed	
Current Condition:	Trap Closed June 2006.				
ST B	Sediment Trap	N41d00m00s W96d00m00s		Removed	
Current Condition:	Sediment trap was removed prior to inspection on 10/5/11 due to re-grading of the area by Double D.				
ST C	Sediment Trap	N41d00m00s W96d00m00s		Removed	
Current Condition:	Sediment trap was removed prior to inspection on 10/5/11 due to re-grading of the area by Double D.				
ST D	Sediment Trap	N41d00m00s W96d00m00s		Removed	
Current Condition:	Sediment trap was removed prior to inspection on 10/5/11 due to re-grading of the area by Double D.				
ST 1	Sediment Trap	North of Replat three Lots 1 and 2	10/5/2011	Active	No
Current Condition:	Good Condition- 9% Filled Sediment trap is installed prior to inspection on 10/5/11 by Double D.				
ST 2	Sediment Trap	Southeast corner of Replat three lot 1	10/5/2011	Active	No

Current Condition:	Good Condition- 8% Filled Sediment trap is installed prior to inspection on 10/5/11 by Double D.				
ST 3	Sediment Trap	Northeast corner of Replat three lot 26	10/5/2011	Active	No
Current Condition:	Good Condition- 10% Filled Sediment trap is installed prior to inspection on 10/5/11 by Double D.				
ST 4	Sediment Trap	North of Replat three Lots 27 and 28	10/5/2011	Active	No
Current Condition:	Good Condition- 11% Filled Sediment trap is installed prior to inspection on 10/5/11 by Double D.				
ST 5	Sediment Trap	Southeast corner of Replat three lot 27	10/5/2011	Active	No
Current Condition:	Good Condition- 8% Filled Sediment trap is installed prior to inspection on 10/5/11 by Double D.				
ST 6	Sediment Trap	Northeast corner of Replat three lot 46	10/5/2011	Active	No
Current Condition:	Good Condition- 6% Filled Sediment trap is installed prior to inspection on 10/5/11 by Double D.				
STR	Streets	N41d14m44s W96d12m59s	8/10/2007	Active	No
Current Condition:	Good Condition-No major signs of track off.				
SWPPP Sign	SWPPP Sign	Two signs on site	3/28/2008	Active	No
Current Condition:	Good Condition On 3/28/08 a SWPPP sign was installed at 164th & Giles and 168th & Meridian St. entrance.				
Inspector Signature:				Reviewed By: 