E & A Consulting Group, Inc. 330 North 117th Street Omaha, NE 68154-2509 tel 402.895.4700 fax 402.895.3599 www.eacg.com



Zachary A. Jilek, CPESC, CISEC

Environmental Services Dept. Manager

## E & A CONSULTING GROUP, INC.

ENGINEERING · PLANNING · ENVIRONMENTAL & FIELD SERVICES

Environmental Services Dept. Mana	•		ANNING • ENVIRONMEN	TAE & FIEED SERVICES
	E&A - F	P2004.045.000		
Inspector: Mike Jacobson, CISEC				Stage
			3	
		Meridian Park		
Project Name:		NER110696		
For Week Ending:		4/13/2013		
Project Location:	168th & Giles	s Street- Omaha, NE (Sa	rpy County)	68136
1 Tojest Essation.	100 4 0	ourour omana, nz (oa	ii py county)	
Grading:	100%			
Sanitary Sewer:	100%			
Storm Sewer:	100%			
Paving:	100%			
Seeding:	100%			
Utilities:	65%			
Overall Development:	45%			
•		· · · · · · · · · · · · · · · · · · ·	•	1
RAIN FALL AMOUNTS	Amount in tenths	Date inspected		
NAME ALL ANIOUNTS	, and an entro	Date inspected		Week 1
Sunday:	0.09"			vveek
Monday	0.00"			
Tuesday	0.00"			
Wednesday	0.00"			
Thursday	0.00"			
Friday	0.00"			
Saturday	0.00"			
Outurudy	0.00			Week 2
Sunday:	0.05"			TICCK 2
Monday	0.00"			
Tuesday	0.00"			
Wednesday	0.00"			
Thursday	0.00"			
Friday	0.00"			
Saturday	0.03"			
				Week :
Sunday:	0.00"			
Monday	0.00"			
Tuesday	0.00"			
Wednesday	0.00"			
Thursday	0.00"			
Friday	0.00"			
Saturday	0.30"			
				Week 4
Sunday:	0.00"			
Monday	0.00"			
Tuesday	0.00"			
Wednesday	0.00"	04/03/13		
Thursday	0.00"			
Friday	0.00"			
Saturday	0.00"			
				Week !
Sunday:	0.21"			
Monday	0.07"			
Tuesday	0.90"			
Wednesday	0.42"	04/10/13		
Thursday	0.00"	04/11/13		

Friday	0.00"					
Saturday	0.00"					
Complaints:	None					
Construction Sequencing:						
Which portion(s) (i.e. drainage basins) of the	site have had a temporary or perr	nanent cessation of g	rading, earthwork, o	or ground disturband	ce in the last 14 days?	
Entire Site, grading completed and site	e seeded Summer/Fall 2005.					
Entire Site, grading was completed in	Replat Three area Lots 1-54	prior to inspection	on 10/5/11 by Do	uble D.		
Which portion's) (i.e. drainage basins) of the	site do not have grading, earthwo	rk, or ground disturba	ance scheduled in th	ne next 14 days?		
Entire Site, grading completed and site	e seeded Summer/Fall 2005					
Entire Oile, grading completed and oil	s secured Cultimoth all 2000.					
Entire Site, grading was completed in	Replat Three area Lots 1-54	prior to inspection	on 10/5/11 by Do	uble D.		
What temporary or permanent stabilization n	neasures listed in this section are	being implemented?				
Site seeded Fall 2005 & 5/2007, stabil		,	,	,		
(9/2008); Areas around where handicap ramps were installed was re-seeded (4/2009); Sediment basin E area was re-seeded(4/2009); Replat						
three lots 1-54 was seeded 10/2011); Replat Three lots 1-54 was re-seeded 4/2012)						
Comments:						
Comments:						
A few homes are under construction in						
Findings / Corrective Actions (Date)	:					
Findings / Corrective Actions (Date)	:					
1) Some maintenance is required in the	e BMP section.					
2) Lots 303 - 308 along 167th Street n						
Company was informed to complete maintenance by 12/22/12. On 1/22/13 and again on 4/3/13 Gabe w/ The Home Company was called and						
left a message reminding him that the lots need to be re-seeded ASAP. Maintenance not completed as of last inspection.						

			Projected		
Unique Name	Туре	Location	Install Date	Status	Maintenance
05.4	0 5 .	N41d00m00s			
CE A	Construction Entrance	W96d00m00s		Removed	
Current Condition:	Entrance Paved	T	T	1	T
		Along 164th			
CW	Concrete Washout Pit	Street		Removed	
Current Condition:	Concrete washout was rem		tion on 7/12/11 h		tone Production
Current Condition.	Concrete washout was form	oved prior to moped	711011 011 77 127 1 1 1	by don without the	none i roddollon.
<b></b>		Along 165th		l	
CW 1	Concrete Washout Pit	Street		Removed	
Current Condition:	Concrete washout was rem	oved prior to inspec	ction on 10/8/12 b	by CS.	
		Lot 241 along			
Lot 241	Silt Fence	Greenfield Street	4/10/2013	Active	No
Current Condition:	Good Condition-				
	Silt fence was installed on the East and South side of lot 241 prior to inspection on 4/10/13 by Dave				
	Hausman/Celebrity Homes.				·
Lots 27 Replat 3	Silt Fence	Lots 27 Replat 3		Removed	
Current Condition:	Silt fence was removed from		pection on 12/4/1	2 by Dave Hausi	man/Celebrity Homes.
	Construction debris appear				
	Legacy Homes				,
	3,				
				I	
Lots 52 Replat 3	Silt Fence	Lot 52 Replat 3	2/26/2013	Active	Yes
Luis JZ Nepiai 3	JIIL I CITUE	Lot 32 Nepiat 3	2/20/2013	Active	169

Current Condition:	Fair Condition-				
	Maintenance was completed prior to inspection on 4/3/13 by Dave Hausman/Celebrity Homes.				
	There is dirt piled behind the lot and it needs to be removed and add silt fence at the back of the lot or add silt fence around dirt pile. Silt fence needs to be installed on the front of the lot.				
	Dave Hausman/Celebrity He completed as of last inspect		to complete mai	ntenance by 4/10	0/13. Maintenance not
Lots 53 Replat 3	Silt Fence	Lots 53 Replat 3	2/26/2013	Active	Yes
Current Condition:	Fair Condition- Maintenance was completed prior to inspection on 4/3/13 by Dave Hausman/Celebrity Homes.				
	One area of silt fence is downdown/damaged and it needs				
	Dave Hausman/Celebrity Ho completed as of last inspect		to complete mai	ntenance by 4/10	0/13. Maintenance not
Lots 54 Replat 3	Silt Fence	Lots 54 Replat 3	2/26/2013	Active	Yes
Current Condition:	Fair Condition- Maintenance was completed	d prior to inspection	on 4/3/13 by Da	ve Hausman/Cel	ehrity Homes
	One area of the silt fence is down/damaged and it needs to be replaced. Silt fence needs to be installed on the front of the lot.  Dave Hausman/Celebrity Homes was informed to complete maintenance by 4/10/13. Maintenance not completed as of last inspection.				
Lots 243	Silt Fence	Lots 243		Removed	
Current Condition:	Silt fence on the back of the Company.	e lot was removed p	rior to inspection	on 12/15/12 by 0	Gabe w/ The Home
POD B	Silt Fence	Lots 63-73		Removed	
Current Condition:	Silt fence is no longer need by Chris w/ Hearthstone Pro		s being sodded ir	this pod prior to	inspection on 6/3/10
POD C	Silt Fence	Lots 97-122		Removed	
Current Condition:	Silt fence is no longer needed due to the all lots being sodded in this pod prior to inspection on 10/5/11 by Jeff w/ Hearthstone Production.				
POD D	Cit Fanas	L - t - 100 100		Damaria	
Current Condition:	Silt Fence   Lots 123-162   Removed    Silt fence is no longer needed due to the all lots being sodded in this pod prior to inspection on 10/5/11 by Jeff w/ Hearthstone Production.				
POD E	Silt Fence	Lots 163-199		Removed	
Current Condition:	Silt fence installed on the back of lot 175 was removed prior to inspection on 9/29/10 by Chris w/ Hearthstone Production due to the lot being sodded. All the homes in this pod have been completed.				
POD F	Silt Fence	Lots 209-217	4/16/2011	Active	Yes

0 10 111	I Factor Occupation				
Current Condition:	Fair Condition- The portable toilet on lot 215 was removed prior to inspection on 4/3/13 by The Home Company.				
	The full dumpster on the lot was emptied prior to inspection on 4/3/13 by The Home Company.				
	1) The silt fence check on lot 215 is down/damaged and it needs to be repaired.				
	2) There is a portable toilet				n
	3) There is dirt piled in the				
	4) There is some trash/con	struction debris on I	ots 211 and 212	and it needs to be	e cleaned up.
	5) One area of silt fence or				
	1) Gabe w/ The Home Con	npany was informed	to complete mail	ntenance by 12/2	2/12. On 1/22/13.
	2/26/13 and again 4/3/13 G				
	ASAP. Maintenance not co				
	2) Gabe w/ The Home Con		to complete mail	ntenance by 4/10	/13. Maintenance not
	completed as of last inspec				40 M : .
	<ol> <li>Gabe w/ The Home Concompleted as of last inspect</li> </ol>		to complete mail	ntenance by 4/10	/13. Maintenance not
	4) Gabe w/ The Home Con		to complete mai	ntenance by 4/10	/13 Maintenance not c
	5) Gabe w/ The Home Con				
	,	. ,	<u>'</u>	ŕ	
		Lots 51-56 along			
POD E	Silt Fence	Meridian Street		Removed	
Current Condition:	This silt fence is being mov	ved to there on lot le	vel BMP as of 9/	14/12.	
		Lots 38-51			
		Meridian Park			
POD G	Silt Fence	Replat Three	4/10/2013	Active	No
Current Condition:	Good Condition-				
	Silt fence was installed on		17 prior to inspec	tion on 4/10/13 by	y Dave
	Hausman/Celebrity Homes	<del></del>	ı	ı	
OD 5	O a d'avec et Dane's	N41d00m00s		D	
SB E Current Condition:	Sediment Basin Basin was removed due to	W96d00m00s	or to increation o	Removed	ublo D Everyating
Current Condition:	basin was removed due to	iot development pri	or to inspection o	iii 6/12/06 by Do	uble D Excavaling.
		N41d00m00s			
SB F	Sediment Basin	W96d00m00s		Removed	
Current Condition:	As of inspection on 5/12/11	1 the basin has beer	filled in by Doub	le D Excavating.	
		N41d00m00s			
SB G	Sediment Basin	W96d00m00s	08/26/05	Active	No
Current Condition:	Good Condition- 15% Fille				
	Partially Cleaned out and b	paffle repaired prior	to inspection on 1	10/12/10 by Bob F	Roth.
		N41d00m00s			
SF A	Silt Fence	W96d00m00s	07/19/05	Removed	
Current Condition:	Removed	1	T	T	
6-5	074 =	N41d00m00s			
SF B	Silt Fence	W96d00m00s	ototivo opera is a	Removed	
Current Condition:	Removed - Not needed du		etative cover in a	nea. I	
SF C	Silt Fence	N41d00m00s W96d00m00s		Removed	
Current Condition:	Removed - Not needed du		etative cover in a		
Current Containon.	removed Normedada da	T to colabilation ca veg	T T T T T T T T T T T T T T T T T T T	1	
		Meridian Park			
SF 1	Silt Fence	Replat 3 Lot 1		Removed	
Current Condition:	Silt fence was removed pri	or to inspection on 1	2/4/12 by Dave H	Hausman/Celebri	ty Homes.
		Meridian Park			
		Replat 3 Lots 26,			
SF 2	Silt Fence	27		Removed	
Current Condition:	Silt fence was removed pri	or to inspection on 1	2/4/12 by Dave H	lausman/Celebri	ty Homes.
		1	I	I	
		Meridian Park			
05.0	CHA Tarasa	Replat 3 Lots 46,		Damestal	
SF 3	Silt Fence	47		Removed	

Current Condition:	Silt fence was removed pr	rior to inspection on 12	2/4/12 by Dave H	Hausman/Celebri	ty Homes.
		N41d00m00s			
ST A	Silt Trap	W96d00m00s		Removed	
Current Condition:	Trap Closed June 2006.	N41d00m00s		T	
ST B	Sediment Trap	W96d00m00s		Removed	
Current Condition:	Sediment trap was remove	ed prior to inspection	on 10/5/11 due t	o re-grading of the	ne area by Double D.
2.7.0	Cadimont Tron	N41d00m00s		Removed	
ST C Current Condition:	Sediment Trap Sediment trap was remove	W96d00m00s ed prior to inspection	on 10/5/11 due t		ne area by Double D.
					, , , , , , , , , , , , , , , , , , , ,
		N41d00m00s			
ST D	Sediment Trap	W96d00m00s	40/5/44	Removed	L. D. H. D.
Current Condition:	Sediment trap was remove	ed prior to inspection	on 10/5/11 due t	o re-grading of the	ne area by Double D.
		North of Replat			
		three Lots 1 and			
ST 1	Sediment Trap	2	10/5/2011	Active	No
Current Condition:	Good Condition- 20% Fille		on 10/5/11 by Do	uplo D	
	Sediment trap was installed	Southeast corner	511 10/5/11 by DC	Duble D.	
		of Replat three lot			
ST 2	Sediment Trap	1	10/5/2011	Active	No
Current Condition:	Good Condition- 30% Fille Sediment trap was installed		on 10/5/11 by Do	nuble D	
	Ocument trap was instance		511 10/5/11 by be	T	I
		Northeast corner of Replat three lot			
ST 3	Sediment Trap	26		Removed	
Current Condition:	This trap was installed price				
	construction taking place i	in the area. The trap	will need to be re	einstalled prior to	Replat 3 Lot 26 being
	Danie Gat.	Between Replat			
		three Lots 26 and			
ST 4	Sediment Trap	27	10/5/2011	Active	No
Current Condition:	Good Condition- 11% Fille Sediment trap was installed		on 10/5/11 by Do	nuble D	
	Occument trap was instance		311 10/3/11 by be	I	I
		Southeast corner			
ST 5	Sediment Trap	of Replat three lot 27		Removed	
Current Condition:	This trap was installed price	or to 10/5/11, but sinc			
	construction taking place i	in the area. The trap	will need to be re	einstalled prior to	Replat 3 Lot 27 being
	Duilt Out.				
		Northeast corner			
ST 6	Sediment Trap	of Replat three lot 46		Removed	
Current Condition:	This trap was installed price		e has been filled		sewer and street
	construction taking place i	in the area. The trap	will need to be re	einstalled prior to	Replat 3 Lot 46 being
	built out.			T	
STR	Streets	N41d14m44s W96d12m59s	8/10/2007	Active	Yes
Current Condition:	Good Condition-	W 300 12111333	0/10/2007	Active	103
	There is track off in the curb lines along lots 212, 213 and 215 and it needs to be cleaned up.				
	Gabe w/ The Home Company was informed to clean up by 4/4/13. Track off was cleaned up prior to				
	inspection on 4/10/13 by The Home Company.				
	SWPPP Sign		- 1		
SWPPP Sign		Two signs on site	3/28/2008	Active	No

	Good Condition On 3/28/08 a SWPPP sign v	vas installed at 164th & Giles and 1	68th & Meridian St. entrance.
Inspector Signature:	Jawlan		Zachany k. Jilak Reviewed By: