

E&A Consulting Group, Inc.  
 330 North 117th Street  
 Omaha, NE 68154-2509  
 tel 402.895.4700  
 fax 402.895.3599  
 www.eacg.com



E&A CONSULTING GROUP, INC.  
 ENGINEERING • PLANNING • FIELD SERVICES

Zachary A. Jilek, CPESC, CISEC  
 Erosion Control Specialist- Manager

**E&A - P2004.020.000**

Inspector: Mike Jacobson, CISEC		Stage 3
Project Name:	<b>Palisades NER110500</b>	
For Week Ending:	<b>1/8/2011</b>	
Project Location:	<b>168th &amp; Cornhusker Road- Omaha, NE (Sarpy County)</b>	<b>68136</b>

RAIN FALL AMOUNTS	Amount in tenths	Date inspected			
					<b>Week 1</b>
Sunday:	0.00"				
Monday	0.00"	12/13/10			
Tuesday	0.00"				
Wednesday	0.06"				
Thursday	0.00"				
Friday	0.00"				
Saturday	Trace				
					<b>Week 2</b>
Sunday:	Trace				
Monday	0.00"				
Tuesday	0.00"				
Wednesday	0.00"				
Thursday	0.02"				
Friday	0.04"				
Saturday	Trace				
					<b>Week 3</b>
Sunday:	Trace				
Monday	0.00"				
Tuesday	0.00"				
Wednesday	Trace				
Thursday	Trace				
Friday	0.24"				
Saturday	0.00"				
					<b>Week 4</b>
Sunday:	0.00"				
Monday	0.00"				
Tuesday	0.00"				
Wednesday	0.00"				
Thursday	0.00"				
Friday	Trace				
Saturday	Trace				
					<b>Week 5</b>
Sunday:	N/A	N/A			
Monday	N/A	N/A			
Tuesday	N/A	N/A			
Wednesday	N/A	N/A			
Thursday	N/A	N/A			
Friday	N/A	N/A			
Saturday	N/A	N/A			

Complaints:	None				
-------------	------	--	--	--	--

**Construction Sequencing:**

Which portion(s) (i.e. drainage basins) of the site have had a temporary or permanent cessation of grading, earthwork, or ground disturbance in the last 14 days?

Entire site; grading completed and site seeded Spring 2005.

Which portion(s) (i.e. drainage basins) of the site do not have grading, earthwork, or ground disturbance scheduled in the next 14 days?

Entire site; grading completed and site seeded Spring 2005.

What temporary or permanent stabilization measures listed in this section are being implemented?

Paving, seeding (Spring 05), dense vegetative cover; Drainage way west of sediment basin 3 was re-graded and seeded/matt (9/2008); Area around SB 3 and where silt was placed was re-seeded (4/2009)

Comments:

**Comments:**  
Home construction is active in various areas on site.

**Findings / Corrective Actions (Date):**

**Findings / Corrective Actions (Date):**  
1) Some required maintenance in the BMP section.

Unique Name	Type	Location	Projected Install Date	Status	Maintenance
Lot 21	Silt Fence	Lot 21		Removed	
<b>Current Condition:</b>	Lot was sodded prior to inspection on 9/20/10 by Urban Homes.				
Lot 22	Silt Fence	Lot 22	9/18/2010	Active	Yes
<b>Current Condition:</b>	<p>No BMP's installed on lot- Vacant lot. Lot was cleaned up prior to inspection on 11/12/10 by Urban Homes.</p> <p>The disturbed areas of the lot needs to be re-seeded and silt fence needs to be installed in a few area to prevent from run off until the vegetation is established on the lot due to the home construction that was on lot 21.</p> <p>Urban Homes was called and left a message informing them to complete the maintenance by 9/26/10. Maintenance not completed as of last inspection. As of inspection on 12/13/10 re-seeding of the lot is not going to take place until next spring due to winter conditions.</p>				
Lot 36	Silt Fence	Lot 36	11/12/2010	Active	No
<b>Current Condition:</b>	Good Condition-Active home construction on lot. Silt fence was installed prior to inspection on 11/12/10 by Regency Homes.				
Lot 81	Silt Fence	Lot 81	8/18/2010	Active	Yes
<b>Current Condition:</b>	<p>No BMP installed on the lot- Active home construction on lot. Silt fence was removed due to the lot being fine graded prior to inspection on 11/12/10 by Sherwood Homes.</p> <p>Silt fence needs to be reinstalled or the lot needs to be sodded.</p> <p>Sherwood Homes was informed to complete maintenance by 12/21/10. On 12/14/10 Sherwood Homes called inspector and stated that they are not responsible for re-installing the silt fence on the back of the lot due to the outlot behind their lot needing to be re-graded. The lot is going to be sodded in the spring. Maintenance not completed as of last inspection.</p>				
Lot 101	Silt Fence	Lot 101	4/9/2010	Active	No
<b>Current Condition:</b>	Good Condition- Vacant lot. Empty lot was cleaned up and the disturbed area was re-seeded prior to inspection on 7/21/10 by Muhle Construction.				
Lot 103	Silt Fence	Lot 103	12/20/2010	Pending	Yes
<b>Current Condition:</b>	<p>Pending- Active home construction on lot.</p> <p>Dirt is piled in the R.O.W. and it needs to be removed or add silt fence around it.</p> <p>Mick Smith Construction was informed to complete maintenance by 12/20/10.</p>				
Lot 109	Silt Fence	Lot 109	12/20/2010	Pending	Yes
<b>Current Condition:</b>	<p>Pending- Active home construction on lot.</p> <p>Dirt is piled in the R.O.W. and it needs to be removed or add silt fence around it.</p> <p>Chris w/ Hearthstone Production was informed to complete maintenance by 12/20/10.</p>				
Lot 110	Silt Fence	Lot 110	12/20/2010	Pending	Yes
<b>Current Condition:</b>	<p>Pending- Active home construction on lot.</p> <p>1) Lot level silt fence needs to be installed on the back of the lot. 2) Dirt is piled in the R.O.W. and it needs to be removed or add silt fence around it.</p> <p>1) Chris w/ Hearthstone Production was informed to complete maintenance by 12/20/10. 2) Chris w/ Hearthstone Production was informed to complete maintenance by 12/20/10.</p>				
Lot 113	Silt Fence	Lot 113	5/4/2010	Active	No
<b>Current Condition:</b>	Good Condition- Silt fence check installed on lot. Vacant lot.				
Lot 134	Silt Fence	Lot 134		Removed	
<b>Current Condition:</b>	Silt fence check on vacant lot was removed prior to inspection on 10/12/10 by Commercial Seeding.				

Lot 180	Silt Fence	Lot 180	11/12/2010	Active	No
<b>Current Condition:</b>	No BMP installed on the lot- Active home construction on lot.				
Lot 185	Silt Fence	Lot 185	11/12/2010	Active	No
<b>Current Condition:</b>	No BMP installed on the lot- Active home construction on lot.				
Lot 291	Silt Fence	Lot 291		Removed	
<b>Current Condition:</b>	Lot was sodded prior to inspection on 12/13/10 by Charleston Homes.				
Lot 292	Silt Fence	Lot 292		Removed	
<b>Current Condition:</b>	Lot was sodded prior to inspection on 12/13/10 by Charleston Homes.				
Lot 299	Silt Fence	Lot 299	12/1/2010	Active	No
<b>Current Condition:</b>	Good Condition- Active home construction on lot. Silt fence was installed on the back of the lot prior to inspection on 12/1/10 by Zych construction.				
Lot 347	Silt Fence	Lot 347	12/13/2010	Active	Yes
<b>Current Condition:</b>	Fair Condition- Active home construction on lot.  Silt fence is down/damaged and needs to be repaired.  Dream Scope Homes was informed to complete maintenance by 12/20/10				
Lot 379	Silt Fence	Lot 379	11/12/2010	Active	No
<b>Current Condition:</b>	Good Condition-Active home construction on lot. Silt fence was installed prior to inspection on 11/12/10 by Zych construction.				
Lot 389	Silt Fence	Lot 389	8/18/2010	Active	Yes
<b>Current Condition:</b>	Pending- Active home construction on lot.  Lot level silt fence needs to be installed on the back of the lot.  Horizon Homes was informed to install silt fence by 8/25/10. On 9/20/10 Horizon Homes was called and left a message reminding them that maintenance needs to be completed ASAP. Maintenance not completed as of last inspection.				
Lot 415	Silt Fence	Lot 415	8/18/2010	Active	Yes
<b>Current Condition:</b>	Pending- Active home construction on lot.  Lot level silt fence needs to be installed on the back of the lot.  Builder is unknown at this time. When builder is determined then they will be informed to complete maintenance.				
SB 1	Sediment Basin	N41d00m00s W96d00m00s	In Place	Active	No
<b>Current Condition:</b>	Good Condition - 31% Filled Cleaned out 06/05				
SB 2	Sediment Basin	N41d00m00s W96d00m00s	In Place	Active	No
<b>Current Condition:</b>	This has been convert to permanent pond for the school site.				
SB 3	Sediment Basin	N41d00m00s W96d00m00s	In Place	Active	No
<b>Current Condition:</b>	Good Condition - 19% Filled Clean out was completed prior to inspection on 1/22/09 by M.E. Collins.				
SB 4	Sediment Basin	N41d00m00s W96d00m00s	In Place	Active	No
<b>Current Condition:</b>	Good Condition - 39% Filled Cleaned out 07/05				
SF 1	Silt Fence	N41d00m00s W96d00m00s		Removed	
<b>Current Condition:</b>	The remainder of silt fence was removed prior to inspection on 8/8/09 by Boyer Young due to good				
ST 1	Silt Trap	N41d00m00s W96d00m00s		Removed	
<b>Current Condition:</b>	Removed; berm constructed and area matted and seeded.				
STR	Streets	N41d00m00s W96d00m00s	In Place	Active	Yes

<b>Current Condition:</b>	Fair Condition- Some minor signs of run off coming from active home construction on lot 347 and it needs to be cleaned up. Bob w/ Dream Scape Homes was informed to clean up by 11/13/10. Maintenance not completed as of last inspection.				
SWPPP Sign	SWPPP Sign	Three signs on site	3/28/2008	Active	No
<b>Current Condition:</b>	Good Condition On 3/28/08 inspector install SWPPP a sign at 172nd & Cornhusker Rd., 168th & Chutney Dr and 168th & Palisades Drive entrance.				
Inspector Signature: <i>Stephen J. Jawlan</i>					Reviewed By: <i>Zachary K. Jirik</i>