


E&A - 2004.020.000				
Inspector: Mike Jacobson				Stage 3
Project Name:	Palisades			
For Week Ending:	1/12/2008			
Grading:	100%			
Sanitary Sewer:	100%			
Storm Sewer:	100%			
Paving:	100%			
Seeding:	100%			
Utilities:	100%			
Overall Development:	39%			
RAIN FALL AMOUNTS	Amount in inches	Date inspected		
				Week 1
Sunday:	0.00"			
Monday	0.20"			
Tuesday	0.21"			
Wednesday	0.00"			
Thursday	0.00"	12/13/07		
Friday	0.04"			
Saturday	0.10"			
				Week 2
Sunday:	0.00"			
Monday	0.00"			
Tuesday	0.00"			
Wednesday	0.00"			
Thursday	0.00"	12/20/07		
Friday	0.00"			
Saturday	0.00"			
				Week 3
Sunday:	0.00"			
Monday	0.00"			
Tuesday	0.00"			
Wednesday	0.00"			
Thursday	0.00"	12/26/07		
Friday	0.01"			
Saturday	0.00"			
				Week 4 / 5
Sunday:	0.00"; 0.00"			
Monday	0.00"; 0.03"			
Tuesday	0.00"; 0.00"	None; 01/08/08		
Wednesday	0.00"; 0.00"	1/2/08; None		
Thursday	0.00"; 0.01"			
Friday	0.00"; 0.00"			
Saturday	0.00"; 0.00"			
Complaints:	None			
Construction Sequencing:				
Which portion(s) (i.e. drainage basins) of the site have had a temporary or permanent cessation of grading, earthwork, or ground disturbance in the last 14 days?				
Entire site; grading completed and site seeded Spring 2005.				
Which portion(s) (i.e. drainage basins) of the site do not have grading, earthwork, or ground disturbance scheduled in the next 14 days? :				
Entire site; grading completed and site seeded Spring 2005.				
What temporary or permanent stabilization measures listed in this section are being implemented?				
Paving, seeding (Spring 05), dense vegetative cover				
Comments:				
Comments: Home construction continues as the main activity on site and school construction has been completed on the east section of the site.				
Findings / Corrective Actions (Date):				

Findings / Corrective Actions (Date):

1) A few lot corners are down.
 On 11/1/07 Boyer & Young was reminded that overdue maintenance needs completed ASAP. Maintenance not completed as of last inspection.
 2) Some required maintenance in the BMP section.

Unique Name	Type	Location	Projected Install Date	Status	Maintenance Scheduled	Description of Maintenance/Activity: Repairs Needed/Planned:
CE 1	Construction Entrance	N41d00m00s W96d00m00s		Removed		
Current Condition:	Removed; 2 paved entrances exist on site.					
SB 1	Sediment Basin	N41d00m00s W96d00m00s	In Place	Active	No	
Current Condition:	Good Condition - 30% Filled Cleaned out 06/05					
SB 2	Sediment Basin	N41d00m00s W96d00m00s	In Place	Active	No	
Current Condition:	Good Condition - 3% Filled Cleaned out 7/07					
SB 3	Sediment Basin	N41d00m00s W96d00m00s	In Place	Active	No	
Current Condition:	Good Condition - 35% Filled Cleaned out 06/05					
SB 4	Sediment Basin	N41d00m00s W96d00m00s	In Place	Active	No	
Current Condition:	Good Condition - 35% Filled Cleaned out 07/05					
SF 1	Silt Fence	N41d00m00s W96d00m00s	In Place	Active	No	
Current Condition:	Good Condition Replaced 04/13/06.					
SF 2	Silt Fence	N41d00m00s W96d00m00s	In Place	Active	Yes	
Current Condition:	Good/Condition One area is full and a few areas needs to be removed due to lots being developed and sodded. On 11/1/07 Boyer & Young was reminded that overdue maintenance needs completed ASAP. Maintenance not completed as of last inspection.					
SF 3		N41d00m00s W96d00m00s		Removed		
Current Condition:	Removed; permanent vegetation					
SF 4	Silt Fence	N41d00m00s W96d00m00s	In Place	Active	Yes	
Current Condition:	Good/ Condition One area is down and needs to be retied. On 11/1/07 Boyer & Young was reminded that overdue maintenance needs completed ASAP.Maintenance not completed as of last inspection.					
SF 5	Silt Fence	N41d00m00s W96d00m00s	In Place	Active	No	
Current Condition:	Good Condition - Major areas have been replaced with lot corner wrap and dense vegetation. Maintanced 4/2007					
SF 6	Silt Fence	N41d00m00s W96d00m00s	1/20/2006	Active	No	
Current Condition:	Good Condition - All has been removed except for the 172nd st. lot corner wrap.					
SF 7	Silt Fence	N41d00m00s W96d00m00s	In Place	Active	No	
Current Condition:	Good/ Condition -Partially remove due to lots be completely developed. -Removed 7/25/07 by Nick Young.					
SF 8	Silt Fence	N41d00m00s W96d00m00s	In Place	Active	No	
Current Condition:	Good Condition Maintanced 11/9/06					
SF 9	Silt Fence	N41d00m00s W96d00m00s	In Place	Active	Yes	
Current Condition:	Good/ Condition One area is down and one area needs to be removed due to lots being developed and sodded. On 11/1/07 Boyer & Young was reminded that overdue maintenance needs completed ASAP. Maintenance not completed as of last inspection.					

SF 10	Silt Fence	N41d00m00s W96d00m00s	In Place	Active	Yes
Current Condition:	<p>Good/ Condition</p> <p>One area is full and a few areas needs to be removed due to lots being developed and sodded.</p> <p>On 11/1/07 Boyer & Young was reminded that overdue maintenance needs completed ASAP. Maintenance not completed as of last inspection.</p>				
ST 1	Silt Trap	N41d00m00s W96d00m00s		Removed	
Current Condition:	Removed; berm constructed and area matted and seeded.				
STR	Streets	N41d00m00s W96d00m00s	In Place	Active	No
Current Condition:	Good Condition - No major signs of track off.				
Inspector Signature: 		Reviewed By: 