

E & A Consulting Group, Inc.
 10909 Mill Valley Road, Suite 100
 Omaha, NE 68154
 tel 402.895.4700
 fax 402.895.3599
 www.eacg.com



Zachary A. Jilek, CPESC, CISEC
 Environmental Services Dept. Manager

E&A - P2004.020.000

Inspector: Branson Starns		Stage 3
Project Name:	Palisades NER110500	
For Week Ending:	10/8/2016	
Project Location:	168th & Cornhusker Road- Omaha, NE (Sarpy County)	68136
Grading:	100%	
Sanitary Sewer:	100%	
Storm Sewer:	100%	
Paving:	100%	
Seeding:	100%	
Utilities:	100%	
Overall Development:	94%	

RAIN FALL AMOUNTS	Amount in tenths	Date inspected	Weather Conditions	
				Week 1
Sunday:	0.00"			
Monday	0.00"			
Tuesday	0.80"			
Wednesday	0.01"	09/14/16	Overcast 68/56	
Thursday	0.01"			
Friday	0.95"	09/16/16	Tstorm 78/61	
Saturday	0.00"			
				Week 2
Sunday:	0.00"			
Monday	0.00"			
Tuesday	0.00"			
Wednesday	0.00"			
Thursday	0.00"			
Friday	0.00"			
Saturday	0.46"			
				Week 3
Sunday:	0.15"			
Monday	0.00"			
Tuesday	0.00"	09/27/16	Clear 76/47	
Wednesday	0.00"			
Thursday	0.00"			
Friday	0.00"			
Saturday	0.00"			
				Week 4
Sunday:	0.00"			
Monday	0.00"			
Tuesday	0.24"			
Wednesday	0.01"			
Thursday	0.63"			
Friday	0.08"	10/07/16	Clear 63/36	
Saturday	0.00"			
				Week 5
Sunday:	0.00"			
Monday	0.00"			
Tuesday	0.00"			
Wednesday	0.00"			
Thursday	0.00"			
Friday	0.00"			
Saturday	0.00"			

Complaints: None

Construction Sequencing:

Which portion(s) (i.e. drainage basins) of the site have had a temporary or permanent cessation of grading, earthwork, or ground disturbance in the last 14 days?
 Entire site; grading completed and site seeded Spring 2005.

Which portion(s) (i.e. drainage basins) of the site do not have grading, earthwork, or ground disturbance scheduled in the next 14 days?
 Entire site; grading completed and site seeded Spring 2005.

What temporary or permanent stabilization measures listed in this section are being implemented?
 Paving, seeding (Spring 05), dense vegetative cover; Drainage way west of sediment basin 3 was re-graded and seeded/matt (9/2008); Area around SB 3 and where silt was placed was re-seeded (4/2009); The drainage area just West of SB 3 was repaired and seeded/matted(10/2011)
 Swale down to basin #3 was regraded, seeded and matted prior to inspection on 9/11/2013; Matting was installed on SB 3 Slopes (8/28/2015).

SUMMARY QUESTIONS:
 Are approved entrances and adjacent streets being maintained adequately?

Yes

Are receiving waters adjacent to the project free of any significant signs of erosion or sediment that would be associated with the construction activity?
No- sediment has left the side from the newly constructed lots.

CHECKLIST QUESTIONS:
 Are waste materials (concrete, construction material, hazardous, etc.) being managed properly?
 yes

Is dust associated with the construction activity adequately controlled on the site?
 Yes

Comments:
 Comments:
 Home construction is active in various areas on site as of the last inspections.

Findings / Corrective Actions (Date):
Findings / Corrective Actions (Date):
 1.) Some required maintenance in the BMP section.
 2.) Bill Miller of Timerblime Homes contacted the inspector on 9/15/16 stating that lot 91 should be sodded as soon as there is favorable weather.

Unique Name	Type	Location	Projected Install Date	Status	Maintenance
CW 1	Concrete Washout	South end of Outlet C along Palisades Drive		Removed	
Current Condition:	Removed- Washout pit was removed by Celebrity Homes prior to 11/12/2015.				
CW 2	Concrete Washout	South end of Outlet C along Palisades Drive		Removed	
Current Condition:	Removed- Washout pit was removed by Boyer Young prior to 11/12/2015.				
CW 3	Concrete Washout	South end of Outlet C along Palisades Drive	8/5/2016	Active	Yes
Current Condition:	Fair Condition- Boyer Young previously removed the concrete pit, however, someone has been dumping material in the designated area. It is unknown who dumped the material in the area. Inspector will determine the proper person to notify for removal of the debris.				
Lot 8	Silt fence	Lot 8		Removed	
Current Condition:	Removed- Lot was sodded by Horizon Homes prior to 11/2/2015.				
Lot 22	Silt fence	Lot 22		Removed	
Current Condition:	Removed- Lot was sodded by Oakwood Homes prior to 11/2/2015.				
Lot 23	Misc./Other	Lot 23		Removed	
Current Condition:	Removed-Regency Homes sodded the lot prior to inspection on 5/8/15.				
Lot 25	Silt fence	Lot 25		Removed	
Current Condition:	Removed- Lot was sodded by The Home Company prior to 11/2/2015.				
Lot 38	Silt fence	Lot 38		Removed	
Current Condition:	Removed- Lot was sodded by Charleston Homes prior to 6/12/2015.				
Lot 39	Silt fence	Lot 39		Removed	
Current Condition:	Removed- Legacy Homes sodded the lot prior to last inspection on 4/14/16.				
Lot 44	Silt fence	Lot 44		Removed	
Current Condition:	Removed- Lot 44 was sodded by THC prior to inspection on 8/22/16 and the silt fence was removed.				
Lot 45	Silt fence	Lot 45		Removed	
Current Condition:	Removed- Charleston Homes sodded the lot prior to 8/18/2015.				
Lot 48	Silt fence	Lot 48	12/21/2015	Active	Yes
Current Condition:	Fair Condition- Timberline Homes sodded the lot prior to inspection on 6/3/16. Natural vegetation is well established on the lot as of 8/22/16. Concrete spoils need to be removed from lot 47. Timberline Homes was informed to complete by 6/11/16. Not done as of last inspection. Timberline Homes was reminded on 7/19/16, 9/1/16, 9/15/16.				
Lot 56	Silt fence	Lot 56		Removed	
Current Condition:	Removed- Charleston Homes sodded the lot prior to inspection on 4/14/16.				
Lot 59	Individual lot	Lot 59		Removed	
Current Condition:	Removed-The lot was sodded by The Home Company prior to inspection on 5/8/15.				
Lot 60	Silt fence	Lot 60		Removed	
Current Condition:	Removed- Lot was sodded by Legacy Homes prior to 11/2/2015.				
Lot 61	Silt fence	Lot 61	6/20/2016	Active	No
Current Condition:	Active- Home Owners Tony and Denise Anderson began construction on the lot prior to inspection on 6/20/16. Stockpiles were removed from the R.O.W. and away from the neighboring fence prior to inspection on 6/30/16. Grade appears insufficient for sediment to enter the streets; Inspector will continue to monitor the front of the lot for BMP's as of 7/3/16. The sidewalk and driveway were paved prior to 10/7/16.				
Lot 77	Silt fence	Lot 77		Removed	
Current Condition:	Removed- H3 Custom Homes sodded the lot prior to inspection on 4/14/16.				
Lot 78	Silt fence	Lot 78		Removed	
Current Condition:	Removed- Lot was sodded by The Home Company prior to 6/12/2015.				
Lot 82	Silt Fence	Lot 82		Removed	
Current Condition:	Removed- Lot was sodded by Timberline Homes prior to the inspection on 4/21/2015.				
Lot 84	Silt fence	Lot 84		Removed	
Current Condition:	Removed- Charleston Homes sodded the lot prior to inspection on 6/3/16.				
Lot 85	Individual lot	Lot 85		Removed	
Current Condition:	Removed-Oakwood Homes sodded the lot prior to inspection on 5/8/15.				
Lot 86	Individual lot	Lot 86		Removed	
Current Condition:	Removed-Jennifer Voss sodded the lot prior to inspection on 5/8/15.				
Lot 87	Silt fence	Lot 87		Removed	
Current Condition:	Removed- Lot has been sodded by THC. As of 8/10/2015, lot has filled in with additional vegetation and will be removed from the report.				
Lot 91	Silt fence	Lot 91		Removed	
Current Condition:	Removed- Timberline Homes sodded the lot prior to inspection on 9/27/16.				

Lot 92	Silt fence	Lot 92		Removed	
Current Condition:	Removed- The Home Company sodded the lot prior to 11/12/2015.				
Lot 163	Silt fence	Lot 163		Removed	
Current Condition:	Removed- TruVision Custom Homes sodded the lot prior to 11/12/2015.				
Lot 164	Silt fence	Lot 164		Removed	
Current Condition:	Removed- the lot was being sodded during the inspection on 6/20/16. The lot was completely sodded as of inspection on 6/30/16.				
Lot 165	Silt fence	Lot 165		Removed	
Current Condition:	Removed- Charleston Homes sodded the lot prior to inspection on 4/14/16.				
Lot 166	Silt fence	Lot 166		Removed	
Current Condition:	Removed- Lot was sodded by Legacy Homes prior to 12/14/2015.				
Lot 168	Silt fence	Lot 168		Removed	
Current Condition:	Removed- Lot was sodded by Logan Home Construction prior to 11/2/2015.				
Lot 178	Silt fence	Lot 178		Removed	
Current Condition:	Removed- Lot was sodded by Legacy Homes prior to 7/31/2015.				
Lot 187	Individual lot	Lot 187		Removed	
Current Condition:	Removed-The lot was sodded by The Home Company prior to inspection on 5/8/15.				
Lot 196	Silt Fence	Lot 196		Removed	
Current Condition:	Removed- Lot was sodded by Homeowner prior to 7/31/2015.				
Lot 197	Silt Fence	Lot 197		Removed	
Current Condition:	Removed- Lot was sodded by Heavican Homes prior to 7/31/2015.				
Lot 198	Silt Fence	Lot 198		Removed	
Current Condition:	Removed- THC sodded and removed the silt fence on the lot prior to inspection on 8/22/16.				
Lot 200	Silt fence	Lot 200		Removed	
Current Condition:	Removed- Charleston Homes sodded the lot prior to inspection on 4/14/16.				
Lot 201	Silt fence	Lot 201		Removed	
Current Condition:	Removed- Charleston Homes sodded the lot and removed the silt fence prior to inspection on 8/22/16.				
Lot 203-204	Silt fence	lot 203-204		Removed	
Current Condition:	Removed- Boyer Young removed the silt fence quite prior to 8/22/16.				
Lot 205	Silt Fence	Lot 205	10/7/2016	Pending	Yes
Current Condition:	Pending- Celebrity Homes started construction on the lot prior to 10/7/16. 1) Silt fence needs to be installed along the side and rear of the lot. 2) Dirt stockpile needs to be removed from the ROW or a wattle/silt fence installed in front of it. 1) Celebrity Homes was informed to complete by 10/14/16. 2) Celebrity Homes was informed to complete by 10/14/16.				
Lot 206	Silt Fence	Lot 206	10/7/2016	Pending	Yes
Current Condition:	Pending- Celebrity Homes started construction on the lot prior to 10/7/16. 1) Silt fence needs to be installed along the side and rear of the lot. 2) Dirt stockpile needs to be removed from the ROW or a wattle/silt fence installed in front of it. 1) Celebrity Homes was informed to complete by 10/14/16. 2) Celebrity Homes was informed to complete by 10/14/16.				
Lot 207	Silt Fence	Lot 207	10/7/2016	Pending	Yes
Current Condition:	Pending- Celebrity Homes started construction on the lot prior to 10/7/16. 1) Silt fence needs to be installed along the side and rear of the lot. 2) Dirt stockpile needs to be removed from the ROW or a wattle/silt fence installed in front of it. 1) Celebrity Homes was informed to complete by 10/14/16. 2) Celebrity Homes was informed to complete by 10/14/16.				
Lot 208	Silt Fence	Lot 208	10/7/2016	Pending	Yes
Current Condition:	Pending- Celebrity Homes started construction on the lot prior to 10/7/16. 1) Silt fence needs to be installed along the side and rear of the lot. 2) Dirt stockpile needs to be removed from the ROW or a wattle/silt fence installed in front of it. 1) Celebrity Homes was informed to complete by 10/14/16. 2) Celebrity Homes was informed to complete by 10/14/16.				
Lot 209	Silt Fence	Lot 209	10/7/2016	Pending	Yes
Current Condition:	Pending- Celebrity Homes started construction on the lot prior to 10/7/16. 1) Silt fence needs to be installed along the side and rear of the lot. 2) Dirt stockpile needs to be removed from the ROW or a wattle/silt fence installed in front of it. 1) Celebrity Homes was informed to complete by 10/14/16. 2) Celebrity Homes was informed to complete by 10/14/16.				
Lots 237-241	Silt Fence	Lots 237-241		Removed	
Current Condition:	Removed- Celebrity Homes sodded the lot 239 prior to 8/28/2015.				
Lots 265-267	Silt Fence	Lots 265-267		Removed	
Current Condition:	Removed- Celebrity Homes sodded the lot 267 prior to 9/9/2015.				
Lot 273	Individual lot	Lot 273		Removed	
Current Condition:	Removed- Lot was sodded by Homebuilders LLC prior to 12/14/2015.				
Lot 290	Silt Fence	Lot 290		Removed	
Current Condition:	Removed- Lot was sodded by Celebrity Homes prior to 7/31/2015.				
Lot 324	Silt Fence	Lot 324		Removed	
Current Condition:	Removed- Outlot E was reseeded and matted by Celebrity Homes prior to 7/31/2015.				
Lot 363-367	Silt fence	Lot 363-367		Removed	
Current Condition:	Removed- Lots 363 and 364 were sodded and the silt fence was removed prior to inspection on 6/20/16. All lots are now sodded and stabilized in this section.				
Lot 378	Silt fence	Lot 378		Removed	

Current Condition:	Removed- Celebrity Homes sodded the lot and removed the existing silt fence prior to inspection on 8/5/16.				
Lot 388	Silt Fence	Lot 388		Removed	
Current Condition:	Removed- Celebrity Homes sodded the lot prior to 9/24/2015.				
Lot 399	Silt fence	Lot 399		Removed	
Current Condition:	Removed- Celebrity Homes sodded the lot prior to inspection on 4/14/16.				
SB 3	Sediment Basin	Commercial Lot #5	In Place	Active	No
Current Condition:	Good Condition - 15% Filled-Cleaned out was completed prior to inspection on 7/31/15 by Dusty Roth.				
SB 4	Sediment Basin	173rd Street and Palisades Drive		Removed	
Current Condition:	Removed- Basin was removed prior to the inspection on 3/24/16.				
STR	Streets	Cornhusker, 168th, and Interior Streets	In Place	Active	No
Current Condition:	Good Condition- The owners of lot 61 cleaned the streets prior to inspection on 8/24/16.				
SWPPP Sign	SWPPP Sign	Three signs on site	3/28/2008	Active	No
Current Condition:	Good Condition- On 3/28/08 inspector installed SWPPPs at 172nd & Cornhusker Rd., 168th & Chutney Dr and 168th & Palisades Drive entrance.				
Inspector Signature:	<i>Brian Stone</i>			Reviewed by:	<i>Sam [Signature]</i>