

E & A Consulting Group, Inc.  
 10909 Mill Valley Road, Suite 100  
 Omaha, NE 68154  
 tel 402.895.4700  
 fax 402.895.3599  
 www.eacg.com



**E & A CONSULTING GROUP, INC.**

*Engineering Answers*

Zachary A. Jilek, CPESC, CISEC  
 Environmental Services Dept. Manager

E&A- P2011.160.006

Inspector: Rhett DeLay		Stage
Project Name:	<b>Ridgeview Apartments CSW-202106011</b>	1
For Week Ending:	<b>11/26/2022</b>	<b>68048</b>
Project Location:	<b>211 S 23RD ST - Plattsmouth, NE (Cass County)</b>	

Grading:	10%			
Sanitary Sewer:	0%			
Storm Sewer:	0%			
Paving:	0%			
Seeding:	0%			
Utilities:	0%			
Overall Development:	5%			

RAIN FALL AMOUNTS	Amount in tenths	Date inspected	Weather Conditions	Time	
					<b>Week 1</b>
Sunday:	0.00"				
Monday:	0.00"				
Tuesday:	0.00"				
Wednesday:	0.00"	11/23/2022	Mostly Cloudy 32/52	9:00 AM	
Thursday:	0.00"				
Friday:	0.00"				
Saturday:	0.82"				

Complaints:	None
-------------	------

**Construction Sequencing:**  
 Which portion(s) (i.e. drainage basins) of the site have had a temporary or permanent cessation of grading, earthwork, or ground disturbance in the last 14 days?

**E&A hired as SWPPP inspector (11/21/22). Entire site active for grading as of (11/23/2022).**

Which portion(s) (i.e. drainage basins) of the site do not have grading, earthwork, or ground disturbance scheduled in the next 14 days?

**E&A hired as SWPPP inspector (11/21/22). Entire site active for grading as of (11/23/2022).**

What temporary or permanent stabilization measures listed in this section are being implemented?

**Existing vegetation (11/23/2022).**

**Checklist Questions:**

**Are receiving waters adjacent to the project free of any significant signs of erosion or sediment that would be associated with the construction activity?**

Yes

**Create Corrective Action?**

N/A

**Have disturbed areas been seeded or otherwise stabilized as required? List inactive portions of the project and if stabilization measure are adequate or needed to prevent erosion.**

Yes

**Create Corrective Action?**

N/A

**Are waste materials (concrete, construction material, hazardous, etc.) being managed properly?**

Yes

**Create Corrective Action?**

N/A

**Are construction entrances and adjacent streets being maintained adequately?**

No

**Create Corrective Action?**

See BMP Section

**Is dust associated with the construction activity adequately controlled on the site?**

Yes

**Create Corrective Action?**

N/A

Comments:

**Comments:**

- 1.) Site was active during the current inspection.
- 2.) E&A hired as SWPPP inspector as of 11/21/22.

**Findings / Corrective Actions (Date):**

**Findings / Corrective Actions (Date):**

- 1.) Some maintenance in BMP Section.

Unique Name	Type	Location	Projected Install Date	Status	Maintenance
CE 01	Construction Entrance	North East Corner	12/1/2022	Pending	Yes
Current Condition:	Pending - A construction entrance should be installed. The Calabretto Building Group was informed to complete by 11/30/22.				
MS 01	Material Storage	Near CE 01		Active	No
Current Condition:	Active - The Calabretto Building Group is storing building materials on site.				
SF 01	Silt Fence	East perimeter	9/9/2022	Active	Yes
Current Condition:	Fair Condition - The Calabretto Building Group installed silt fence prior to the inspection on 11/23/22. The silt fence needs to be extended along the eastern perimeter The Calabretto Building Group was informed to complete by 11/30/22.				
SF 02	Silt Fence	Eastern Slope	12/1/2022	Pending	No
Current Condition:	Pending - E&A inspector will continue to monitor.				
STR	Streets	ADJ and Internal Streets	10/31/2022	Active	No
Current Condition:	Good Condition- No major signs of track off.				
SWPPP Sign	SWPPP Signs	Adjacent to CE 1	9/30/2022	Pending	No
Current Condition:	Pending - E&A inspector ordered a SWPPP sign 11/29/22. E&A inspector will install SWPPP sign when it is received from the shop.				
WO 01	Concrete Washout	On site	12/1/2022	Pending	No
Current Condition:	Pending - A concrete washout will be installed on site as necessary.				
WS 01	Waste Storage Area	On site		Pending	No
Current Condition:	Pending - The waste storage area will be installed as necessary.				

Inspector Signature: 

Reviewed By: 