

E & A Consulting Group, Inc.
 10909 Mill Valley Road, Suite 100
 Omaha, NE 68154
 tel 402.895.4700
 fax 402.895.3599
 www.eacg.com



E & A CONSULTING GROUP, INC.

Engineering Answers

Zachary A. Jilek, CPESC, CISEC
 Environmental Services Dept. Manager


E&A - P2001.059.000

Inspector: Aaron Tulley		Stage
Project Name:	Walnut Creek Hills	3
For Week Ending:	3/14/2020	
Project Location:	96th and Gold Coast Road- Papillion, NE (Sarpy County)	68046

Grading:	100%			
Sanitary Sewer:	100%			
Storm Sewer:	100%			
Paving:	100%			
Seeding:	100%			
Utilities:	100%			
Overall Development:	95%			

RAIN FALL AMOUNTS	Amount in inches	Date inspected	Weather Conditions	Inspection Time	
					Week 1
Sunday:	0.00"				
Monday	0.00"				
Tuesday	0.00"				
Wednesday	0.05"				
Thursday	0.00"				
Friday	0.00"				
Saturday	0.00"				
					Week 2
Sunday:	0.00"				
Monday	0.02"				
Tuesday	0.00"				
Wednesday	0.08"				
Thursday	0.00"				
Friday	0.00"				
Saturday	0.00"				
					Week 3
Sunday:	0.00"				
Monday	0.00"				
Tuesday	0.00"				
Wednesday	0.00"	2/26/2020	Partly Cloudy 39/24	2:45 PM	
Thursday	0.00"				
Friday	0.00"				
Saturday	0.00"				
					Week 4
Sunday:	0.00"				
Monday	0.01"				
Tuesday	0.00"				
Wednesday	0.01"				
Thursday	0.00"				
Friday	0.00"				
Saturday	0.00"				
					Week 5
Sunday:	0.00"				
Monday	0.30"				
Tuesday	0.00"				
Wednesday	0.00"				
Thursday	0.00"				
Friday	0.04"				
Saturday	0.45"				

Complaints:	None
--------------------	------

Construction Sequencing:					
Which portion(s) (i.e. drainage basins) of the site have had a temporary or permanent cessation of grading, earthwork, or ground disturbance in the last 14 days?					
Entire site; grading completed and site seeded prior to 2005.					
Which portion(s) (i.e. drainage basins) of the site do not have grading, earthwork, or ground disturbance scheduled in the next 14 days? :					
Entire site; grading completed and site seeded prior to 2005.					
What temporary or permanent stabilization measures listed in this section are being implemented?					
Paving, dense vegetation and landscaping installed prior to 2005. Vacant lots 1, 2, and 3 replat 20 have been seeded (4/27/19).					
Checklist Questions:					
Are receiving waters adjacent to the project free of any significant signs of erosion or sediment that would be associated with the construction activity?					
Yes					
Create Corrective Action?					
N/A					
Have disturbed areas been seeded or otherwise stabilized as required? List inactive portions of the project and if stabilization measures are adequate or needed to prevent erosion.					
Yes					
Create Corrective Action?					
N/A					
Are waste materials (concrete, construction material, hazardous, etc.) being managed properly?					
Yes					
Create Corrective Action?					
N/A					
Are construction entrances and adjacent streets being maintained adequately?					
Yes					
Create Corrective Action?					
N/A					
Is dust associated with the construction activity adequately controlled on the site?					
Yes					
Create Corrective Action?					
N/A					
Comments:					
Comments: Grading has begun for Trinity Lutheran Church on vacant Lots 1, 2, and 3 Replat 20. Project and silt fence is being inspected by TD2. E&A will continue to inspect SB 1. Grading for storm sewer in vacant Lots 1, 2, and 3 Replat 20. Trinity Lutheran Church project was active as of the last inspection.					
Findings / Corrective Actions (Date):					
Findings / Corrective Actions (Date): 1) No required maintenance in the BMP section. 2) TD2 will be informed to attempt to prevent sediment going into SB 1 as of 3/19/19. No BMPs installed or stabilization measures as of the last inspection. It appears the vacant Lots 1, 2, and 3 Replat 20 have been seeded prior to inspection on 4/27/19. E&A will continue to monitor.					
Unique Name	Type	Location	Projected Install Date	Status	Maintenance Scheduled
SB 1	Sediment Basin	41°08'23.73"N 96°03'19.85"W	In Place	Active	No
Current Condition:	Fair Condition - 51% Full. SB 1 was cleared of vegetation prior to inspection on 2/22/18. The basin is filling with sediment from the adjacent unstabilized Lots 1, 2, and 3 Replat 20 associated with the Trinity Lutheran Church project being managed by TD2. Due to basin being closed in the near future, E&A will not be recommending cleanout at this time. E&A will continue to monitor.				
STR	Streets	41°08'17.47"N 96°03'13.01"W	In Place	Active	No
Current Condition:	Good Condition - No signs of track out				
SWPPP Sign	Signs	3 Signs		Removed	
Current Condition:	Removed - All signs have been removed or are unable to be located as of 12/20/16. Signs will not be reinstalled due to site being inactive and almost complete. If work resumes a new sign will be ordered and installed.				
Inspector Signature: 			Reviewed By: 