E & A Consulting Group, Inc. 10909 Mill Valley Road, Suite 100 Omaha, NE 68154 tel 402.895.4700 fax 402.895.3599 www.eacg.com



Zachary A. Jilek, CPESC, CIS Environmental Services Dept				Engineering Answers		
		E&A- P2021.	065.002			
Inspector: Josh Ellington					Stage	
Project Name:		Westridge Estates				
For Week Ending:	8/6/2022				68073	
Project Location:	Highway	Highway 77 West of Eagle Drive - Yutan, NE (Saunders County)				
			•	• •		
Grading:	55%	0				
Sanitary Sewer:	0%	b l				
Storm Sewer:	0%	b				
Paving:	85%	5				
Seeding:	0%	5				
Utilities:	0%	5				
Overall Development:	0%	Ď.				
RAIN FALL AMOUNTS	Amount in tenths	Date inspected	Weather Conditions	Time		
					Week 1	
Sunday:	0.00"					
Monday:	0.00"					
Tuesday:	0.00"	8/2/2022	Sunny 102/76	10:20 AM		
Wednesday:	0.02"					
Thursday:	0.00"					
Friday:	0.00"					
Saturday:	0.00"					
Complaints:	None					
Construction Conversion						
Construction Sequencing: Which portion(s) (i.e. drainage basin	ns) of the site have had a tempor	rary or normanent cossa	tion of grading earthwork or o	around disturbance in the l	aet 14 daye?	
which portion(s) (i.e. dramage basin	is) of the site have had a tempor	ary or permanent cesso	ation of grading, earthwork, or g	ground disturbance in the h	ust 14 days:	
Stripping and grading began (5	/17/2022).					
	<u> </u>					
Which portion(s) (i.e. drainage basir	ns) of the site do not have gradir	ng, earthwork, or ground	disturbance scheduled in the	next 14 days?		
Stripping and grading began (5	/17/2022).					
What temporary or permanent stabil	lization measures listed in this s	ection are being implen	nented?			
Existing vegetation (5/17/2022)).					
Checklist Questions:						
1.) Are receiving waters adjace construction activity?	cent to the project free of	any significant sign	s of erosion or sediment	that would be associa	ited with the	
Yes						
Create Corrective Action?						
N/A						

2.) Have disturbed areas been seeded or otherwise stabilized as required? List inactive portions of the project and if stabilization measured.
are adequate or needed to prevent erosion.

Yes

Create Corrective Action?

N/A

3.) Are waste materials (concrete, construction material, hazardous, etc.) being managed properly?

No

Create Corrective Action?

No - See BMP section

4.) Are construction entrances and adjacent streets being maintained adequately?

No

Create Corrective Action?

No - See BMP section

5.) Is dust associated with the construction activity adequately controlled on the site?

Yes

Create Corrective Action?

N/A

Comments:

Comments:

1.) Site was inactive during the last inspection.

Findings / Corrective Actions (Date):

Findings / Corrective Actions (Date):

1.) Some maintenance is required in the BMP section.

Unique Name	Туре	Location	Projected Install Date	Status	Maintenance		
CE 01	Construction Entrance	H16	5/17/2022	Active	Yes		
Current Condition:	Fair Condition - 79% effective - Existing gravel drive will function as construction entrance as of the first inspection on 5/17/22. Rock should be added to the construction entrance. Summit Development was informed to complete by 7/20/22. Not done as of last inspection.						
D 01	Diversion	J11 to H9	6/7/2022	Pending	No		
Current Condition:	Pending - The diversion will be installed once grading in the area requires. E&A inspector will continue to monitor						
D 02	Diversion	J11 to I13	6/7/2022	Pending	No		
Current Condition:	Pending - The diversion will be installed once grading in the area requires. E&A inspector will continue to monit						
D 03	Diversion	J10 to 17	5/17/2022	Active	No		
Current Condition:	Good Condition - The grader installed the diversion prior to the first inspection on 5/17/22. The diversion has be removed prior to the inspection on 7/19/22 due to grading activity. E&A inspector will monitor to recommend reinstallation.						
MS 01	Material Storage	On Site	6/7/2022	Pending	No		
	Pending - The material storage will be installed as necessary.						
Current Condition:	Fending - The materia	ıı storage wili be iristali	eu as necessary.				
Current Condition: PT 01	Portable Toilet	On Site	7/13/2022	Active	Yes		
	Portable Toilet Fair Condition - Sumn Portable toilet should	On Site nit Development installe be secured.		the inspection on 7			
PT 01	Portable Toilet Fair Condition - Sumn Portable toilet should	On Site nit Development installe be secured.	7/13/2022 ed the portable toilet prior to	the inspection on 7			

Current Condition:	Pending - Silt fence will be installed once necessary due to grading on site. E&A inspector will monitor.						
SF 02	Silt Fence	I13 to G16	6/7/2022	Pending	No		
Current Condition:	Pending - Silt fence will be installed once necessary due to grading on site. E&A inspector will monitor.						
STR	Streets	ADJ and Internal Streets	5/17/2022	Active	No		
Current Condition:	Good Condition- No major signs of track off.						
SWPPP Sign 01	SWPPP Signs	Adjacent to CE 1	6/7/2022	Active	No		
Current Condition:	Good Condition - E&A inspector installed the SWPPP sign during the inspection on 6/6/22.						
W 01	Straw Wattles	G16	6/7/2022	Pending	No		
Current Condition:	Pending - The straw wattles will be installed on site as necessary. The E&A inspector will continue to monitor.						
W 02	Straw Wattles	G16	6/7/2022	Pending	No		
Current Condition:	Pending - The straw w	attles will be installed or	n site as necessary. The l	E&A inspector will cor	ntinue to monitor.		
WO 01	Concrete Washout	On site	6/7/2022	Active	No		
Current Condition:	Good Condition - Summit Development installed the concrete washout prior to the inspection on 7/13/22.						
WO 02	Concrete Washout	On site	7/13/2022	Active	Yes		
Current Condition:	Fair Condition - Summit Development installed the concrete washout prior to the inspection on 7/13/22. Concrete waste not in the washout should be removed. Summit Development was informed to complete by 7/20/22. Not done as of last inspection.						
WS 01	Waste Storage Area	On site	6/7/2022	Active	Yes		
Current Condition:	Active - Summit Development installed the waste storage prior to the inspection on 7/13/22.						
Certification Statement:							
Inspector Signature:	Je			Reviewed By:	G. 4 S. 4		