

Legend

- FSF Fabric Silt Fence
See Details, sheet C-2
- Curb Inlet Protection
See Details, sheet C-2

General Notes:

- 1) All work shall conform to the City of Omaha "Soil Erosion and Sediment Control Manual", current edition.
- 2) Maximum slope shall be 3:1 for all non-stabilized slopes.
- 3) Any disturbed areas shall be seeded as soon as construction operations are complete.
- 4) Fabric Silt Fence and Curb Inlet Protection shall be left in place and maintained until permanent vegetation has been established.
- 5) Erosion Control Measures shall be inspected on a minimum of a monthly basis and within 24 hours after a storm event of 0.5 inches of more. Any deficiencies shall be repaired within 24 hours after deficiency has been observed.

JULY 27th INSPECTION NOTES

- ① REPAIR FENCE
- ② CLEAN FENCE
- ③ CLEAN MUD FROM ROADWAY
- ④ INSTALL FENCE AT LOCATION SHOWN ON EROSION CONTROL PLAN

NORTH

1 inch = 100 ft.


DESIGNED: JMM
 DRAWN: JMM
 CHECKED: DOH
 DATE: 3/30/05

**PRELIMINARY
 - NOT FOR
 CONSTRUCTION**

**CLEARWATER FALLS
 SANITARY AND IMPROVEMENT DISTRICT NO. 243
 SARPY COUNTY, NEBRASKA**

EROSION CONTROL PLAN

HILL-FARRELL ASSOCIATES, INC.
 Architects • Engineers • Surveyors
 1008 Lincoln Road, Bellevue, NE 68005 (402) 291-6100



PROJECT NO.
C02019

SHEET NO.

© 2005 Hill-Farrell Associates, Inc. These plans are specifically designed by Hill-Farrell Associates, Inc. for construction and are intended for no other purpose. Any use or alteration of this document, in part or whole, without the written permission or consent of Hill-Farrell Associates, Inc. is prohibited.

H:\Projects\2005\050710\050710.dwg Plot File: 050710.dwg Plot Date: 05/27/05 09:11:11 AM Plot Scale: 1/4" = 1'-0" Plot Orientation: Landscape